NFPA 24 private fire mains and hydrants check list ✓ Is this check list applicable? NO All information shall be provided per NFPA 24:4.1.3 prior to construction? _____ Design/installation shall comply with City Code Ch. 10 and Fire Department Regulations Ch 2: What is the minimum fire main size serving a fire hydrant? _____ What is the minimum fire flow available from the water supply? _____ If the water supply is stored water, what is the quantity available? _____ The completed Contractor's Material and Test Certificate for Underground Piping shall be provided at the completion of the job? _____ The completed City of Portland Test and Maintenance Report and Hydrant Flow Test Report shall be provided at the completion of the job? _____

* See Applicant Submittal Requirements for Electronic Plan Review.

Separate permits are required for internal and external plumbing, & electrical installations.

For questions on Fire Department requirements call the Fire Prevention Officer at (207) 874-8405.

Please submit all of the information outlined in this application checklist. If the application is incomplete, the application may be refused.

In order to be sure the City fully understands the full scope of the project, the Planning and Development Department may request additional information prior to the issuance of a permit. For further information or to download copies of this form and other applications visit the Inspections Division on-line at www.portlandmaine.gov, or stop by the Inspections Division office, room 315 City Hall or call 874-8703.

This is not a Permit; you may not commence any work until the Permit is issued.