

---

---

## MEMORANDUM

---

---

**To:** FILE

**From:** Nell Donaldson

**Subject:** Application ID: 2015-027

**Date:** 3/23/2015

---

**Comments Submitted by: Bruce Hyman/Parks on 3/10/2015**

\*\* The bike parking concrete pads should be a minimum of 8' in length and 6' in width (9'x6' better) to ensure their functionality - it's a little hard to scale accurately from the 11x17 plans - they may be that already.

\*\* We do not require the detectable warning panels at the 3 driveways: they are only for crossings of public ways and signalized driveways.