Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/27/17

**Home Office**
170 Kittyhawk Ave.
P.O. Box 1390
Auburn, ME 04210-1390
207-784-1507

# EASTERN FIRE

*FIRE PROTECTION CONTRACTORS AND ENGINEERS*

*www.easternfiregroup.com*

**Satellite Office**
408 Harlow St.
Bangor, ME 04401
207-942-8014

To: City of Portland, ME – Portland Fire Department

From: Colby Malcolm, Eastern Fire

Re: Apothecary by Design – 1st Floor Server Room

Date: 4/20/17

Apothecary by Design is a single-story business occupancy currently protected by a fully automatic supervised fire sprinkler system interconnected with a manual fire alarm system. The fire alarm system is monitored by a remote central station.

The owner has requested an alternative to sprinkler protection be installed in the current server room to avoid the possibility of water discharging on any sensitive equipment. A new NOVEC 1230 fire suppression system will be installed in the server room consisting of cross zoned smoke detection and manual controls. A connected reserve will also be installed ensuring little to no down time in protection within the space. Upon owner request the fire sprinkler head will be plugged within the server room.

Please don't hesitate to contact with any questions. Thank you

Colby Malcolm
Eastern Fire
malcolmcr@easternfiregroup.com
207-784-1507