



ELECTRICAL LIGHTING PLAN  
SCALE: 1/8" = 1'-0"

- NOTES:**
- 1) SEE ELECTRICAL PANEL SCHEDULE REFER DRAWING FOR VOLTAGE REQUIREMENTS.
  - 2) TRADER JOE'S TO FINISH ALL INTERIOR LIGHT FIXTURES, UNLESS OTHERWISE NOTED. TENANT GENERAL CONTRACTOR TO INSTALL.
  - 3) TENANT TO SUPPLY, INSTALL, AND WIRE ALL EXTERIOR LIGHT FIXTURES INCLUDING EXTERIOR LIGHTING OVER BEERES DOORS. 1) DOOR LIGHTING AS PANEL WITH THE EXCEPTION OF THE DOOR LIGHTS, BEERES & BEERES LIGHTS. DRAWINGS FOR CEILING TO TRADER JOE'S PANEL, SEE ELECTRICAL DRAWINGS FOR CEILING.
  - 4) ALL LIGHT SWITCHES AND LIGHTING SENSORS TO BE MOUNTED AT 5'-2" AFF. (TYPICAL).
  - 5) GENERAL LIGHTING ON SALES FLOOR ARE REQUIRED TO PANEL. 1) TO BREAKERS SPACES INDICATED NEXT TO PANELS.
- CEILING GRID NOTES:**  
THE CEILING GRID LOCATION SHALL BE BASED ON CENTERING THE 2' X 4' LIGHT FIXTURE ROW BETWEEN (1) FROZEN FOOD CASES AND ABLE TENANT GENERAL CONTRACTOR SHALL VERIFY WITH TJS REP THE EXACT LOCATION OF THE CEILING GRID PRIOR TO INSTALLATION.

- GENERAL NOTES:**
1. ALL WORK SHALL BE IN ACCORDANCE WITH THE 2011 NATIONAL ELECTRICAL CODE (NEC) AND ALL LOCAL CODES. ALL WIRING SHALL BE IN ACCORDANCE WITH THE 2011 NATIONAL ELECTRICAL CODE (NEC) AND ALL LOCAL CODES.
  2. THE ELECTRICAL CONTRACTOR SHALL VERIFY THE EXISTING CONDITIONS TO INSURE THAT THE NEW WORK WILL FIT TO THE EXISTING CONDITIONS. THE CONTRACTOR SHALL SHOW ON THE DRAWINGS IN RED ALL CONDITIONS THAT ARE CONTRARY TO THOSE ON THE DRAWINGS. THE CONTRACTOR SHALL VERIFY THE EXISTING CONDITIONS PRIOR TO FABRICATION OR PERFORMANCE OF ANY WORK IN THE FORM OF A DRAWING OR SECTION INDICATING FIELD MODIFICATIONS AND NOTES RELATED TO THE AREA.
  3. ROUTE CONTROLLED LIGHTING CIRCUITS THRU NEW PANELBOARDS. REFER TO PANEL SCHEDULES AND LIGHTING CONTROL DETAILS FOR ADDITIONAL REQUIREMENTS.
  4. ALL NEW LIGHTS, EMERGENCY AND EXIT LIGHTS SHALL BE LIGHTING CONTROL SYSTEM.
  5. THE NORMAL BALLAST OF THE "E" FIXTURES SHALL BE CONTROLLED BY THE LIGHTING CONTROL SYSTEM. THE WIRING SHALL BE IN ACCORDANCE WITH THE LIGHTING CONTROL SYSTEM. REFER TO PANEL SCHEDULES AND THE EXISTING BALLAST AND LIGHTING WIRING DRAWING.
  6. NO CIRCUIT SHALL BE RUN EXPOSED ON THE EXTERIOR OF THE BUILDING. ALL EXTERIOR LIGHTS SHALL BE CONCEALED WITHIN THE BUILDING STRUCTURE. REFER TO THE LIGHTING CONTROL SYSTEM DRAWING FOR ADDITIONAL REQUIREMENTS.
  7. ALLOW FOR 5% (5) APPROXIMATE SCOT LIGHTS TO BE ALLOWED AS DIRECTED BY THE LOCAL AIA.

WALL SWITCH SPECIFICATIONS:  
\$ INTERIORS MODEL, ETR66 WALL SWITCH WITH CONTINUOUS TRIP

**dp** DON PENN CONSULTING ENGINEER  
639 WESTPORT PARKWAY SUITE 300  
GRAPEVINE, TEXAS 75051  
817.410.2858 FAX 817.231.8411

**PROJECT** **TRADER JOE'S**  
87 MARGINAL WAY  
PORTLAND, ME. 04101

**SHEET NAME**  
**ELECTRICAL LIGHTING PLAN**

SALES :	17,224 sq. ft.	DATE	04/28/10
STOCK :	5,424 sq. ft.	JOB No.	FT-1912
MISC. :	1,464 sq. ft.	DRAWN BY:	FTA
TOTAL :	23,930 sq. ft.	TENANT STORE No.	XXXX
		SPACE No.	XXXX

REVISIONS		COMMENTS
NO.	DATE	

**Jeffrey Taylor**  
Architect

572 North Broadway  
White Plains, N.Y. 10603  
Tel 914 298 0011  
Fax 914 298 0022