

**... Fire Protection by Computer Design**

High Tech Fire Protection  
84 Hackett Mills Rd  
PO Box 156  
Poland, ME, 04274  
207-998-2551

Job Name : BAYSIDE BOWL  
Building : 2  
Location : 58 Alder Street  
System : 2  
Contract : 033116-2  
Data File : Wet Calc.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** BAYSIDE BOWL  
**Location:** 58 Alder Street  
**Drawing no:** 2  
**Date:** 10-7-16

**Design**

**Remote area number:** 2  
**Remote area location:** Above Pinsetting Area  
**Occupancy classification:** Light Hazard  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 1500 - SqFt  
**Coverage per sprinkler:** 225 - SqFt  
**Type of sprinklers calculated:** QR  
**No. of sprinklers calculated:** 12  
**In-rack demand:** - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 340 - GPM @ 91 - Psi  
**Type of system:** NFPA 13 Wet  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 10/28/2014  
**Location:** Corner of Kennebec St and Preble St  
**Source:** Portland Water District

**Name of contractor:** High Tech Fire Protection  
**Address:** 84 Hackett Mills Rd / PO Box 156 / Poland, ME, 04274  
**Phone number:** 207-998-2551  
**Name of designer:** Ed Pennell  
**Authority having jurisdiction:** Portland Fire Department  
**Notes: (Include peaking information or gridded systems here.)**


# Water Supply Curve (C)

High Tech Fire Protection  
BAYSIDE BOWL

Page 2  
Date 10-7-16

City Water Supply:  
C1 - Static Pressure : 102  
C2 - Residual Pressure: 50  
C2 - Residual Flow : 1061

Demand:  
D1 - Elevation : 18.450  
D2 - System Flow : 239.421  
D2 - System Pressure : 90.191  
Hose ( Demand ) : 100  
D3 - System Demand : 339.421  
Safety Margin : 5.495



# Fittings Used Summary

High Tech Fire Protection  
BAYSIDE BOWL

Page 3  
Date 10-7-16

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

High Tech Fire Protection  
BAYSIDE BOWL

Page 4  
Date 10-7-16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
W1	42.6	5.6	16.14	na	22.5	0.1	225	7.0
W2	42.6	5.6	16.37	na	22.66	0.1	225	7.0
W3	42.6	5.6	17.2	na	23.22	0.1	225	7.0
W4	42.6	5.6	18.97	na	24.39	0.1	225	7.0
W5	37.6		27.88	na				
W6	37.6		29.03	na				
P*	0.0		34.59	na				
W7	42.6	5.6	16.31	na	22.62	0.1	225	7.0
W8	42.6	5.6	16.54	na	22.78	0.1	225	7.0
W9	42.6	5.6	17.37	na	23.34	0.1	225	7.0
W10	42.6	5.6	19.17	na	24.52	0.1	225	7.0
W11	37.6		28.14	na				
W12	37.6		29.3	na				
W13	42.6	5.6	22.58	na	26.61	0.1	225	7.0
W14	42.6	5.6	22.89	na	26.79	0.1	225	7.0
W15	37.6		29.73	na				
W16	37.6		30.14	na				
W17	17.4		55.48	na				
W18	17.4		59.26	na				
W19	17.4		74.52	na				
W20	6.6		79.32	na				
W21	6.6		79.36	na				
TOR	1.0		81.82	na				
BOR	-1.0		89.7	na				
UG1	-1.0		89.86	na				
UG2	-1.0		90.37	na				
UG3	-1.0		90.57	na				
TEST	0.0		90.19	na	100.0			

The maximum velocity is 14.09 and it occurs in the pipe between nodes W16 and W17

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
BAYSIDE BOWL

Page 5  
Date 10-7-16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
W1 to W2	22.50 22.5	1.682 120.0 0.0162		0.0 0.0 0.0	14.000 0.0 14.000	16.143 0.0 0.227		K Factor = 5.60		
W2 to W3	22.66 45.16	1.682 120.0 0.0589		0.0 0.0 0.0	14.000 0.0 14.000	16.370 0.0 0.825		K Factor = 5.60		Vel = 3.25
W3 to W4	23.22 68.38	1.682 120.0 0.1269		0.0 0.0 0.0	14.000 0.0 14.000	17.195 0.0 1.777		K Factor = 5.60		Vel = 6.52
W4 to W5	24.39 92.77	1.682 120.0 0.2231	1V	4.331 0.0 0.0	25.900 4.331 30.231	18.972 2.166 6.745		K Factor = 5.60		Vel = 9.87
W5 to W6	0.0 92.77	2.157 120.0 0.0664	1T	12.307 0.0 0.0	5.000 12.307 17.307	27.883 0.0 1.150				Vel = 13.40
W6 to W12	0.0 92.77	2.635 120.0 0.0251		0.0 0.0 0.0	10.800 0.0 10.800	29.033 0.0 0.271				Vel = 8.15
	0.0 92.77					29.304		K Factor = 17.14		
W7 to W8	22.62 22.62	1.682 120.0 0.0164		0.0 0.0 0.0	14.000 0.0 14.000	16.311 0.0 0.230		K Factor = 5.60		Vel = 3.27
W8 to W9	22.77 45.39	1.682 120.0 0.0594		0.0 0.0 0.0	14.000 0.0 14.000	16.541 0.0 0.832		K Factor = 5.60		Vel = 6.55
W9 to W10	23.34 68.73	1.682 120.0 0.1281		0.0 0.0 0.0	14.000 0.0 14.000	17.373 0.0 1.794		K Factor = 5.60		Vel = 9.92
W10 to W11	24.52 93.25	1.682 120.0 0.2253	1V	4.331 0.0 0.0	25.900 4.331 30.231	19.167 2.166 6.810		K Factor = 5.60		Vel = 13.46
W11 to W12	0.0 93.25	2.157 120.0 0.0671	1T	12.307 0.0 0.0	5.000 12.307 17.307	28.143 0.0 1.161				Vel = 8.19
W12 to W16	92.77 186.02	2.635 120.0 0.0908		0.0 0.0 0.0	9.250 0.0 9.250	29.304 0.0 0.840				Vel = 10.94
	0.0 186.02					30.144		K Factor = 33.88		
W13 to W14	26.61 26.61	1.682 120.0 0.0221		0.0 0.0 0.0	14.000 0.0 14.000	22.578 0.0 0.310		K Factor = 5.60		Vel = 3.84
W14 to W15	26.79 53.4	1.682 120.0 0.0803	1V	4.331 0.0 0.0	53.900 4.331 58.231	22.888 2.166 4.676		K Factor = 5.60		Vel = 7.71
W15 to W16	0.0 53.4	2.157 120.0 0.0239	1T	12.307 0.0 0.0	5.000 12.307 17.307	29.730 0.0 0.414				Vel = 4.69

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
BAYSIDE BOWL

Page 6  
Date 10-7-16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
W16 to W17	186.02 239.42	2.635 120.0 0.1448	1X	14.827 0.0	99.700 14.827 114.527	30.144 8.749 16.588		Vel = 14.09		
W17 to W18	0.0 239.42	2.635 120.0 0.1448	1V	5.903 0.0	20.200 5.903 26.103	55.481 0.0 3.781		Vel = 14.09		
W18 to W19	0.0 239.42	2.635 120.0 0.1449	1V 2X	5.903 29.654 0.0	69.800 35.557 105.357	59.262 0.0 15.261		Vel = 14.09		
W19 to W20	0.0 239.42	6.357 120.0 0.0020	2V	25.147 0.0	33.300 25.147 58.447	74.523 4.677 0.116		Vel = 2.42		
W20 to W21	0.0 239.42	6.357 120.0 0.0020	1V	12.573 0.0	11.500 12.573 24.073	79.316 0.0 0.048		Vel = 2.42		
W21 to TOR	0.0 239.42	6.357 120.0 0.0020	1V	12.573 0.0	4.750 12.573 17.323	79.364 2.425 0.035		Vel = 2.42		
TOR to BOR	0.0 239.42	6.357 120.0 0.0020	1Fsp	0.0 0.0	5.600 0.0 5.600	81.824 7.866 0.011		* Fixed loss = 7 Vel = 2.42		
BOR to UG1	0.0 239.42	6.16 140.0 0.0017	1E 1G 1T	20.084 4.304 43.037	22.000 67.425 89.425	89.701 0.0 0.156		Vel = 2.58		
UG1 to UG2	0.0 239.42	6.16 140.0 0.0017	1T	43.037 0.0	250.000 43.037 293.037	89.857 0.0 0.510		Vel = 2.58		
UG2 to UG3	0.0 239.42	6.16 140.0 0.0017	1T	43.037 0.0	75.000 43.037 118.037	90.367 0.0 0.206		Vel = 2.58		
UG3 to TEST	0.0 239.42	6.16 140.0 0.0017	1E 1G	20.084 4.304 0.0	5.000 24.388 29.388	90.573 -0.433 0.051		Vel = 2.58		
	100.00 339.42					90.191		Qa = 100.00 K Factor = 35.74		