

Application ID Number: 2015-049

Delete Review

Distribution: 03/23/2015

Add Review

Current Status: Comments Submitted

Reviewer: Keith Gautreau

Approval Date

Department: Fire

Expiration Date

Extension Date

Comments

Status: Date: 4/1/2015

Comment: It's look as though access will be good, at least two sides possibly three depending on Lancaster.



Fire Comments:

Memo

All construction and installation shall comply with 2009 NFPA 1, 2009 NFPA 101.

Status: Date: 4/1/2015

Comment: Building  
The new building shall not affect the egress or required Fire Department access for the neighboring building.  
Hydrants  
2009 NFPA 1 18.3 Water Supplies and Fire Hydrants



-Fire Department Connections shall not be located where large diameter hose may block egress.

Memo

Create Date: 03/23/2015 By ldobson Update Date: 04/01/2015 By gautreauk

Save Close

Print

Print