DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

KENNEBEC KROSSING LLC

Located at

101 HANOVER ST- 137 Kennebec

PERMIT ID: 2014-01978

ISSUE DATE: 09/11/2014

CBL: 034 K004001

has permission to Install free standing sign (24" x 45.5") and building wall sign (46" x 94") for

"Parlour"

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

multiple uses in building - retail & personal services

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

 City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Status: Approved

Permit No: 2014-01978

Date Applied For: 09/02/2014

CBL:

034 K004001

09/10/2014

Proposed Use:

Hair Salon "Parlour"

Dept: Zoning

Proposed Project Description:

Reviewer: Ann Machado

Install free standing sign (24" x 45.5") and building wall sign (46" 94") for "Parlour"

Note: B-7 zone - individual ground floor tenant

Ok to Issue: 🗹

Approval Date:

free standing sign

-16 sf max. - 7.6 sf propsoed - OK

- 6' max - 5' given - OK

- 5' from property lines - ok per plot plan

building Sign

 $-2 \times 40' = 80 \text{ sf max.} - 30 \text{ sf - OK}$

Conditions:

Dept: Building **Status:** Approved w/Conditions **Reviewer:** Tammy Munson **Approval Date:** 09/04/2014

Note: Ok to Issue: ✓

Conditions:

1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code.

- 2) Encroachments into public ways must be a minimum of 8' above grade for signs and 7' for awnings per section 3202 of IBC 2009.
- 3) Separate Permits shall be required for any new signage.
- 4) The sidewalk sandwich sign shall not infringe on the City Right of Way

PERMIT ID: 2014-01978 **Located at:** 101 HANOVER ST- 137 Kennebec **CBL:** 034 K004001