


- GENERAL NOTES:**
- 1) EC TO CLEAN AND RELAMP ALL EXISTING INTERIOR AND EXTERIOR LIGHT FIXTURES.
 - 2) ALL NEW FLUORESCENT LUMINAIRES SHALL HAVE DISCONNECTING MEANS TO COMPLY WITH NEC 410.13(G).
 - 3) EXISTING LIGHT FIXTURES SHOWN FOR REFERENCE ONLY.

- KEY NOTES:**
- 1) RELENS FIXTURE. MATCH EXISTING LENS TYPE.
 - 2) FIXTURES TO REMAIN SUSPENDED FROM EXISTING SAFETY CABLES DURING CEILING GRID REPLACEMENT. REINSTALL IN NEW CEILING GRID AT THE EXISTING LOCATION.
 - 3) REMOVE EXIT SIGN FROM ABOVE DOOR. REMOVE WIRE AND CONDUIT BACK TO SOURCE. MAINTAIN CONNECTION TO EXIT SIGNS THAT ARE TO REMAIN.
 - 4) REPLACE TRACK HEADS ON THE EXISTING PRODUCE SALES TRACK. NEW TRACK HEADS TO BE ELECTRA-LED MODEL TLC-15-5-27-DD. QUANTITY AND LOCATION SHALL BE AS SHOWN ON PLAN. PROVIDE A NOKIA 3 CIRCUIT ADAPTER FOR EACH HEAD.
 - 5) CONTRACTOR SHALL CONNECT FIXTURE TO THE CIRCUIT OF THE ADJACENT FIXTURE AS SHOWN.
 - 6) INSTALL NEW SWITCH AND RECONNECT THE EXISTING FIXTURE TO THE EXISTING CIRCUIT. SURFACE MOUNT FIXTURE ON NEW CEILING.
 - 7) REMOVE SALES LIGHTING IN THE WINE SALES AREA. REMOVE WIRE AND CONDUIT BACK TO SOURCE. MAINTAIN CIRCUIT CONTINUITY TO FIXTURES THAT ARE TO REMAIN.
 - 8) REPLACE TRACK HEADS ON THE EXISTING PRODUCE SALES RING TRACK. NEW TRACK HEADS TO BE ELECTRA-LED MODEL TLC-15-5-27-DD. QUANTITY AND LOCATION SHALL BE AS SHOWN ON PLAN. PROVIDE NOKIA GESTO 1 CIRCUIT MONOPOINT ADAPTER FOR EACH HEAD.
 - 9) TRACK TO BE T-TRAK 700T8H9060S. INSTALL WITHIN EXISTING CAFE RINGS. INSTALL ACCULAMP TRACK HEADS ALSO SHOWN IN LOCATION SHOWN.
 - 10) INSTALL NEW SINGLE CIRCUIT TRACK WITH SILVER FINISH. TRACK HEADS TO BE ELECTRA-LED MODEL TLC-15-5-27-27-DD. QUANTITY AND LOCATION SHALL BE AS SHOWN ON PLAN.
 - 11) RELOCATE EXISTING LIGHT FIXTURE. EXTEND WIRE AND CONDUIT TO THE NEW LOCATION.

A LIGHTING PLAN
1/8" = 1'-0"

NOTE:
PLAN SCALE
1/8" = 1'-0"
WHEN PRINTED ON
A 36" X 48" SHEET



3	11/19/11	ISSUED FOR CONSTRUCTION
2	10/21/11	ISSUED FOR HANNAFORD 100% REVIEW
1	09/29/11	ISSUED FOR HANNAFORD 60% REVIEW
0	09/14/11	ISSUED FOR HANNAFORD REVIEW
No.	Date	Revision

Project Title:
REMODEL HANNAFORD SUPERMARKET & PHARMACY STORE #8351 - 295 FOREST AVENUE PORTLAND, MAINE 04101

Prepared By:
JACOBS
JACOBS ENGINEERING GROUP INC. 164001808
1000 Connecticut Avenue, N.W. Washington, D.C. 20036
5700 Major Boulevard, Suite 400
Portland, ME 04103-2001 Fax: 407-893-5199

Electrical Engineer of Record
NAME: JOSEPH HARRILL, P.E.
MAINE REGISTERED PEI: 17107

Lighting Plan
Scale: 3/32" = 1'-0"
Date: 10/21/11

Designed by: J. HARRILL
Drawn by: J. HARRILL
Checked by: L. PEREZ

Drawing No.
E101
Project No.
PRYR0300
IBC-PORTLAND, ME