



BOYKO ENGINEERING
 JAMES BOYKO, P.E.
 11D Gorham Industrial Parkway
 Gorham, Maine 04038
 tel. (207) 856-1900
 fax. (207) 856-1999

REVISIONS	NUMBER	DATE	DESCRIPTION
Issued for construction	0	11/18/11	

Date: AUGUST, 2011
 Drawn By: PDS
 Checked By: BEI
 Project Mgr: BEI
 Project No: 0
 Client: Hannaford Supermarket & Pharmacy No. 8351
 295 FOREST AVENUE
 PORTLAND, MAINE 04101

REFRIGERATION PIPING
 SALES AREA
 RACK B LINE SIZING
 HANNAFORD SUPERMARKET & PHARMACY No. 8351
 295 FOREST AVENUE
 PORTLAND, MAINE 04101

LEGEND/NOTES

- | | | |
|--------------------------|---|--|
| REFRIGERATION #S: | PIPING SYMBOLS: | KEYED NOTES: |
| A* (-20F suction) | — ABOVE SLAB PIPING | ① INSTALL PIPING PER "REFRIGERATION SYSTEMS PIPING & INSTALLATION SPECIFICATION", ON R2 DRAWING. |
| B* (+20F suction) | - - - - - BELOW SLAB PIPING | ② CONTRACTOR SHALL PROVIDE ALL BALL VALVES SHOWN. |
| C* (+15F suction) | — PIPE TERMINATION | ③ BUNDLED VERTICAL PIPING AS TIGHTLY AS POSSIBLE. BOX-OUT PER OWNER'S INSTRUCTIONS. |
| | ⊕ RISERS | ④ DROP ALONG COLUMN LINE. |
| | — MACHINE ROOM CONNECTIONS | ⑤ CONNECT TO CASES ALONG TOP OF LINEUP. |
| | — FULL PORT BALL VALVES, TO MATCH LINESIZE
INSTALL 1/4" ANGLE VALVE ON EVAP SIDE
NOTE: INSTALL BALL VALVES AS NEAR TO GROUND LEVEL AS POSSIBLE. | ⑥ TO CONCEAL PIPING, DROP TO CEILING 4FT (min.)
BACK FROM VERTICAL WALL. |