



LEGEND/NOTES

REFRIGERATION #S:
 A* (-20F suction)
 B* (-20F suction)
 C* (-15F suction)

PIPING SYMBOLS:
 — ABOVE SLAB PIPING
 - - - BELOW SLAB PIPING
 — PIPE TERMINATION
 — RISERS
 — MACHINE ROOM CONNECTIONS
 — FULL PORT BALL VALVES, TO MATCH LINESIZE
 — INSTALL 1/4" ANGLE VALVE ON EVAP SIDE
 NOTE: INSTALL BALL VALVES AS NEAR TO GROUND LEVEL AS POSSIBLE.

KEYED NOTES:
 ① INSTALL PIPING PER "REFRIGERATION SYSTEMS PIPING & INSTALLATION SPECIFICATION", ON R2 DRAWING.
 ② CONTRACTOR SHALL PROVIDE ALL BALL VALVES SHOWN, BOX-OUT PER OWNER'S INSTRUCTIONS.
 ③ BUNDLED VERTICAL PIPING AS TIGHTLY AS POSSIBLE, BOX-OUT PER OWNER'S INSTRUCTIONS.
 ④ DROP ALONG COLUMN LINE.
 ⑤ CONNECT TO CASES ALONG TOP OF LINEUP.
 ⑥ TO CONCEAL PIPING, DROP TO CEILING 4FT (min.) BACK FROM VERTICAL WALL.

BOYKO ENGINEERING
 JAMES BOYKO, P.E.
 11D Gorham Industrial Parkway
 Gorham, Maine 04038
 tel. (207) 856-1900
 fax. (207) 856-1999

REVISIONS	NUMBER	DATE	DESCRIPTION
Issued for construction	0	11/18/11	

Date: AUGUST, 2011
 Drawn By: POS
 Checked By: BEI
 Project Mgr: BEI
 Project No:
 Civil File/Forest Ave. Refrigeration.dwg
 Graphic
 Plotter:
 © copyright 2011 James Boyko, Inc.

REFRIGERATION PIPING
SALES AREA
RACK C LINE SIZING
HANNAFORD SUPERMARKET & PHARMACY No.8351
 295 FOREST AVENUE
 PORTLAND, MAINE 04101