Dave Gobeil

Plumbing and Heating and Mechanic

199 Cleaves Street
Biddeford, Maine 04005
207-233-1270
gobeil_dave@yahoo.com

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/05/13

2x4 16" on center

The studs need to be metal.

2x4 wood wall 16" on center

10' high wooden walls

ADD 3'0 door for

handi-cap Bathroom

All interior stops are 2x4 wood

Framed