

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

HANNAFORD BROS CO #351C

Located at

295 FOREST AVE

PERMIT ID: 2016-02903

ISSUE DATE: 01/20/2017

CBL: 034A C001001

has permission to **Interior renovation of produce cooler and restrooms.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.	A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	---

/s/ David Petruccelli

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

retail grocery

Building Inspections

Use Group: M

Type: 2B

Mercantile

Existing occupanct load to remain

NFPA 13 sprinkler system

First Floor

MUBEC/IBC 2009

Fire Department

PERMIT ID: 2016-02903

Located at: 295 FOREST AVE

CBL: 034A C001001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Plumbing Under Slab
Close-in Plumbing/Framing
Electrical Close-in
Above Ceiling Inspection
Final - Commercial
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02903	Date Applied For: 11/18/2016	CBL: 034A C001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Shopping Center - "Hannaford's Supermarket & Pharmacy"		Proposed Project Description: Interior renovation of produce cooler and restrooms.		
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 01/19/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.				
<hr/>				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 01/20/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
<hr/>				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 11/22/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: David Petrucci	Approval Date: 01/20/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.				
2) Construction or installation shall comply with City Code Chapter 10.				
3) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.				
4) All outstanding code violations shall be corrected prior to final inspection.				
5) A separate Fire Alarm Permit is required for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.				
6) A separate Suppression System Permit is required for all suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
7) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
8) Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.				

- 9) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 10) **The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.**
A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.
- 11) The approved plans with the Building Department Approved stamp shall be maintained on site for inspection.
- 12) Shall comply with NFPA 101 (2009) Ch. 37 Existing Mercantile Occupancies
- 13) All electrical and fire alarm work shall be conducted under Maine electrical license
- 14) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.