



LEFT SIDE PARTIAL
SPRINKLER PLAN
SCALE: 1/4" = 1'-0"

SUBMITTAL COPY

1. Type of Hazard	LIGHT/ORDINARY	2. Deflector Distance	PER SPEC
3. Pipe Type Used	BLK_SCH_10/40	4. Sprinkler Area	PER SPEC
5. Type of Construction	NON COMBUSTIBLE		
6. Maximum Spacing Allowed	PER NFPA 13		
7. PIPE SIZING METHOD: PIPE SCHEDULE	<input type="checkbox"/> HYDRAULICALLY CALCULATED		
8. ALL HANGERS AND LOCATIONS TO BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13			
9. HIGH DEGREE TEMPERATURE SPRINKLER HEADS TO BE INSTALLED IN ACCORDANCE WITH NFPA PAMPHLET NO. 13			



HANGER DETAILS
N.T.S.

HANGERS	
AS SHOWN IN DETAIL	

ABBREVIATIONS	
B	Bottom of Beam
D	Bottom of Deck
P	Bottom of Pipe
HV	Head Valve
N & C	Net in Contact
NIS	Net to Scale
DBJ	Open Bar Joints
PRV	Pressure Red Valve
RM	Roof Manifold
SP	Standpipe
TDB	Top of Deck
TSP	Top of Pipe
TOS	Top of Steel
UN	Unusual Otherwise Noted
CL	Centerline
NAS	Not Automatic Sprinklers
DTA	Open to Above

CONTRACT RESPONSIBILITIES		
ITEM	FPC	OTHERS
STREET CORN		
LUIG MAN		
EXCAVATION		
FLUSHING		
WIRING		
PAINTING		
TAMPER SWITCHES		
FLOW SWITCHES		
STREET CORN		

SPRINKLER HEAD LEGEND										
SYMBOL	MAKE	MODEL	SIN	FINISH	TYPE	TEMP	NPT	ORIFICE	K-FACTOR	TOTAL
	RELIABLE	F1FR 56	RA1414	CHROME	SOI-FRG PENDING	155° F	1/2"	1/2"	5.6	5
	RELIABLE	F3GR 56	RS714	CHROME	DRY PENDING	200° F	1"	1/2"	5.6	5
TOTAL → 10										

SUBMITTALS	
DATE SENT	03/30/16
DATE RECEIVED	
I.S.O.	
F.M.	
L.R.I.	
L.A.	
STATE FIRE	<input checked="" type="checkbox"/>
LOCAL FIRE	<input checked="" type="checkbox"/>
LOCAL WATER	<input checked="" type="checkbox"/>
OWNER	<input checked="" type="checkbox"/>

LICENSE# 093
R.M.S.# 442

PERMIT # N/A

P.O. BOX 1285
LEWISTON MAINE
04243-1285

HANNAFORD FOREST AVE PORTLAND, MAINE 04101		CONTRACT WITH ZACAUH CONSTRUCTION	
SYSTEM TYPE	NO.	DATE	REVISIONS
WET			
DRY			
DELUGE			
PREACTION			
ME. LIFE			
HYDRO-PRO			
TOTAL SPKRS ON JOB		10	
SHEET#		1 of 1	
JOB#		17-002 TM	