

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
CITY OF PORTLAND

Located at
356 STATE ST

PERMIT ID: 2013-01129 ISSUE DATE: 06/14/2013 CBL: 035 I001001

has permission to **2013 Southern Maine Pride Day; Staging Setup 06/14, take down 6/15/2013 - to set up twelve 10'10 canopies around town on Parade route ie Congress Sq., Tommy's Park, P.O. Park etc.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Jon Rioux

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
City Park - Deering Oaks

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Site VISIT

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01129	Date Applied For: 06/04/2013	CBL: 035 I001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Deering Oaks- City Park		Proposed Project Description: 2013 Southern Maine Pride Day; Staging Setup 06/14, take down 6/15/2013 - to set up twelve 10'10 canopies around town on Parade route ie Congress Sq., Tommy's Park, P.O. Park etc.		
Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 06/04/2013	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Building	Status: Approved w/Conditions	Reviewer: Jon Rioux	Approval Date: 06/14/2013	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This permit DOES NOT authorize any construction activities. The tent/stage must be removed at the end of the event.				
2) A separate electrical permit is required for the temporary lighting, heat, or power.				
Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing.				
3) 108.2 Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general welfare.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Chris Pirone	Approval Date: 06/05/2013	
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
1) All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.				
2) Cooking within the tents has not been reviewed and approved.				
3) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not within 5 feet of the tents or an exit discharge.				
4) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.				
5) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.				