

NATIONAL SYSTEMS CONTRACTORS ASSOCIATION

NSCA Membership Certificate

This is to certify that

Norris Inc

is an official member of the
National Systems Contractors Association
on this the

First of December

Nancy Emerson

Nancy Emerson
President

Chuck R. Wilson

Chuck Wilson
Executive Director

NSCA



Norris Inc
 2257 West Broadway
 South Portland, ME 04106
 1-800-370-3473

**** SUBMITTAL ****

3/21/2008

Project Number: 33722

For :
Keller Williams Realty 291-293 State Street, Portland Customer P.O.: X

** SUBMITTAL ** to:
NEW CUSTOMER . .
Tel: .

Project Site:
Keller Williams Realty Linda Mansfield/Chris Lavoie
50 Sewall Street PORTLAND, ME 04102 Tel: 207-553-2604

Mfr-Part No.	Qty Description	Unit Price	Extended
	Fire Alarm System, 291-293 State Street:		
NOTIFIER-MS2410B	1 Fire - Control Panel, 10 zone, 2.5A		
Notifier-PS-1270	2 Battery 7 ah		
ADI-MO-RJ31X	2 SFS MT 8C RJ31X UL (917UL)		
ADI-MO-362	2 (91628)P TO Y RJ CORD 8C 2FT		
RMS1TKL	8 Pullstation, Red Die Cast (Notifier key)		
NOTIFIER-2W-B	8 i3 Photo Detector, 2-wire, 12/24 Vdc, Photo.		
NOTIFIER-5601P	2 135 iF (57i C) fixed and rate-of-rise. (Plain)		
NOTIFIER-5602	1 194 iF (90i C) fixed and rate-of-rise.		
NOTIFIER-NS-24MC W-FR	6 Horn Strobe, 24vdc, Multi Candela		
NOTIFIER-MIZ-24S-R	3 Mini-Horn, 24 Vdc, Red, Sync w/ built-in temporal.		
SPECIAL-KNOXS	0 Knox Box, surface mount, no tamper (furnished by owner)		
	1 Cable, misc. material and permits		
	1 Customer Discount		
	Installation		
NOR-MON QUOTE FA	1		
	The cost to have your alarm system monitored by our local, twenty-four hour, UL Listed central station will be \$27.00 per month billed annually in advance. This will require two active phone lines in the building, however they do not have to be dedicated phone lines. The communicator will transmit an automatic test signal every 24 hours for NFPA code compliance.		