

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager PARKSIDE PROPERTIES		Inspector		Inspection Date 4/6/2005	
Location 17 GRANT ST	CBL 036 D015001	Status Re-Inspect 30 Days		Inspection Type Complaint-Inspection	

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1)	-				
Violation:					
Notes:					
2)	6-113.5	Interior	1	2	Hall
Violation: Maintenance of lighting fixtures					
Notes: Front Hall inoperative light fixture					
3)	6-113.5	Interior	1	2	Bathroom
Violation: Maintenance of lighting fixtures					
Notes: Inoperative light fixture					
4)	6-111.4	Interior	1	2	Bathroom
Violation: Maintenance of plumbing fixtures.					
Notes: Bathroom toilet partial blockage					
5)	6-116.5	Interior	1	2	Various locations
Violation: Fire Protection					
Notes: Missing Smoke detector					

Comments: Smoke detectors MUST be replaced and working within 24 hours of this notice.