

INSPECTION WORKSHEET (141352) FOR CITY OF PORTLAND FIRE DEPT

Case Numbe Inspection D Inspector:		Inspection Status: Re-i	nit Management nspection required Routine Fire Inspec	tion
Job Address	: 5 Grant St Portland, ME 04101	Parcel Number:		
Contact Type	e Company Name	Name		
Checklist Item		Passed : No Comments: Please contact the the Fire Department for a reinspection after all violations have been corrected.		
Noncomplia	ance			
Code Name NFPA 101-4.5.3.2, 7.1.10.1	Description Obstructed Egress	Comments IMMEDIATELY remove all obstructions to the me of egress. Storage on the secondary exit.	Deadline eans 06/15/2018	Resolve Date
NFPA 101-8.5	Smoke Barrier Requires Maintenance	Missing ceiling tiles in the basement.	06/15/2018	