



Jeff Levine, AICP, Director  
Planning & Urban Development Department

Ann Machado  
Zoning Administrator

### NFPA LIFE SAFETY CODE – FIRE PREVENTION CODE DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal non-conforming dwelling units to become legalized through a given process. Part of this process is that the dwelling units that are requested to be legalized MUST comply, or be able to comply, with the NFPA Life Safety Code – Fire Prevention Code, PRIOR to issuing the requested permit.

Please return this form to the Zoning Administrator as to compliance or the ability to comply with these codes.

Location: 461 Cumberland Ave. 36-F-18

Owner: East End Corp. Steve Whittier

Address of owner: P.O. Box 10291, Portland ME 04104 879-6081

(If different)

Applicant Information: \_\_\_\_\_

(If different):

Current number of legal units: fifteen (15)

Number of units to be legalized: two (2)

total sixteen (16)

Comments of approval or disapproval (List any and all conditions):

Hardwired battery backup smoke detection required each bedroom  
Hardwired battery back-up CO detection required in common area in unit.  
Unit #2 requires number. - Emergency lighting requires repair.

Signature: [Signature] Date: 9/24/15