

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

EAST END CORP

Located at

461 CUMBERLAND AVE

PERMIT ID: 2015-02316

ISSUE DATE: 10/05/2015

CBL: 036 F018001

has permission to **For the legalization of two (2), existing, non-conforming units, bringing the total to 16 units.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

sixteen dwelling units

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02316	Date Applied For: 09/23/2015	CBL: 036 F018001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Multi-Family (16 Units)		Proposed Project Description: For the legalization of two (2), existing, non-conforming units, bringing the total to 16 units.		
<hr/>				
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 10/01/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) No exterior alterations of any kind are approved with this permit.				
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 10/01/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note: Housing Letter on microfiche from 1978 - 16 units				
Conditions:				
1) This property shall remain a sixteen family dwelling. Any change of use shall require a separate permit application for review and approval.				
2) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
<hr/>				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/25/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit recognizes a pre-existing land use and does not require or certify compliance with the City's current building code. The inspection performed will be done pursuant to the City's Minimum Standards for Housing, The Housing Code. All violations shall be corrected prior to the final inspection and the issuance of the Certificate of Occupancy. This does NOT authorize any construction activities.				
2) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level.				
The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.				
3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messenger	Approval Date: 09/30/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) All violations listed on NFPA Code Compliance letter shall be corrected.				
2) Shall meet the requiremnets of NFPA 101,Chapter 31, Existing Apartment Buildings.				
3) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
4) All construction shall comply with City Code Chapter 10.				