
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager OLD CUMBERLAND ASSOCIATES		Inspector Jon Rioux	Inspection Date 2/21/2007
Location 447 CUMBERLAND AVE	CBL 036 F020001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.3	Exterior		Apt. 26		03/31/2007
Violation:	Exterior windows, doors and skylights				
Notes:	Repair and or replace the spare-room window so that it is substantially weather-tight, watertight, and in sound working condition and good repair. Every exterior window shall include storm sash with screens or an alternative equally effective for heat retention and ventilation purposes.				

Comments: