
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

| | | | |
|---|---------------------------|-------------------------------|--|
| Owner/Manager SEA OTTER LIMITED LIABILITY | | Inspector Jon Rioux | Inspection Date 2/22/2007 |
| Location 87 EMERY ST | CBL 056 G004001 | Status | Inspection Type Complaint-Inspection |

| Code | Int/Ext | Floor | Unit No. | Area | Compliance Date |
|-------------------|---|--------------|-----------------|--------------|------------------------|
| 1) 6-116.5 | Interior | | | Smoke Alarms | 02/16/2007 |
| Violation: | Fire Protection | | | | |
| Notes: | Replace all hard-wire/ battery back-up smoke detectors in each unit; this shall include Apt. 1 and 2 at 87 Emery St. and Apt 3. at 85 Emery St. | | | | |

Comments: