



FOREST AVENUE

**BASEMENT FIRE ALARM PLAN**  
SCALE: 1/4"=1'-0"

**FCP Battery Calculation** 11/17/2014

PROJECT NAME: 102 PORTLAND STREET  
Required Standby Time: 24 Hours  
Required Alarm Time: 3 Minutes

Device Type	Number of Devices	Current (Amps)	Total Current (Amps)
MS-9050UD Main Circuit Board	1	0.12000	0.12000
ANN-80 Remote Annunciator	1	0.01500	0.01500
S0355 Smoke Detectors	8	0.00030	0.00240
H355 Heat Detectors	29	0.00030	0.00870
BG-121X Pull Stations	5	0.00023	0.00115
<b>TOTAL STANDBY LOAD</b>			<b>0.14725</b>

  

Regulated Load in ALARM	Number of Devices	Current (Amps)	Total Current (Amps)
MS-9050UD Main Circuit Board	1	0.20000	0.20000
ANN-80 Remote Annunciator	1	0.04000	0.04000
Max Alarm Draw - All Addressable Devices	1	0.40000	0.40000
MNC-1 (See voltage drop codes for device quantity)	1	0.84300	0.84300
MNC-2	1	0.63800	0.63800
<b>TOTAL ALARM LOAD</b>			<b>2.12100</b>

  

**Battery Requirements**

Standby Load Current (I <sub>sb</sub> )	0.14725	X	Required Standby Time in Hours	36
Alarm Load Current (I <sub>al</sub> )	2.12100	X	Required Alarm Time in Hours	0.17675
Total Ampere Hours (before derating factor)				3.71075
Derating Factor				1.2
<b>TOTAL AMPERE HOURS REQUIRED</b>				<b>4.45290</b>

**BATTERIES TO BE PROVIDED (2 - 12V)** = 7 AH

**MNC Circuit Voltage Drop Calculation** 11/13/2014

Project Name: 102 PORTLAND STREET  
Circuit Number: MNC-1

Nominal System Voltage: 20.4 volts  
Minimum Device Voltage: 16 volts  
Distance from source to 1st device: 10  
Wire Gauge for balance of circuit: 14

Max Output Current: 1.3 amps  
Total Circuit Current: 0.843 amps

Device	Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.178	30	20.35	0.05	0%
Device 2	0.178	30	20.23	0.17	1%
Device 3	0.069	30	20.13	0.27	1%
Device 4	0.069	30	20.06	0.42	2%
Device 5	0.066	30	19.99	0.41	2%
Device 6	0.066	15	19.96	0.44	2%
Device 7	0.107	15	19.94	0.46	2%
Device 8	0.079	35	19.93	0.47	2%
<b>Totals</b>		<b>200</b>			

**MNC Circuit Voltage Drop Calculation** 11/13/2014

Project Name: 102 PORTLAND STREET  
Circuit Number: MNC-2

Nominal System Voltage: 20.4 volts  
Minimum Device Voltage: 16 volts  
Distance from source to 1st device: 50  
Wire Gauge for balance of circuit: 14

Max Output Current: 1.0 amps  
Total Circuit Current: 0.638 amps

Device	Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.017	15	20.20	0.20	1%
Device 2	0.079	25	20.13	0.26	1%
Device 3	0.017	25	20.06	0.34	2%
Device 4	0.017	40	19.94	0.47	2%
Device 5	0.079	40	19.90	0.50	2%
Device 6	0.017	15	19.82	0.58	3%
Device 7	0.079	40	19.80	0.60	3%
Device 8	0.017	25	19.77	0.63	3%
Device 9	0.079	25	19.74	0.66	3%
Device 10	0.017	25	19.72	0.68	3%
Device 11	0.079	25	19.71	0.69	3%
Device 12	0.017	15	19.71	0.69	3%
Device 13	0.017	15	19.71	0.69	3%
Device 14	0.017	25	19.71	0.69	3%
<b>Totals</b>		<b>345</b>			

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	11/17/2014

**CUNNINGHAM**  
**Security Systems**  
10 Princes Point Road, Yarmouth, Maine 04096  
Office: 207.846.3350 • Fax: 207.846.6080

**120 PORTLAND STREET**  
**PORTLAND, MAINE 04101**  
**BASEMENT FIRE ALARM PLAN & CALCULATIONS**

**UNIGAD**  
INC.  
574 W. 40TH ST.  
PORTLAND, ME 04102  
OFFICE: 603.863.6110  
WWW.UNIGAD.COM

Drawn: JPB UNIGAD JOB #14726  
Checked: WYNNE B. HAWK NCEIT #V 90496  
Date: 11/17/2014  
Revision: 0  
Scale: 1/4"=1'-0"

**FA-2**

RESERVED FOR CITY STAMP