



# Non-Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 67 Forest Ave/409 Cumberland CBL: 036 H09001  
 Exact location: (within structure) Ground Floor lounge<sup>Ave</sup> and exhibition kitchen  
 Type of occupancy(s) (NFPA & ICC): Residential Apartments (57) Accessory Assembly, NFPA 13  
 Building owner: Avesta 409 Cumberland LP sprinkled  
 Managing Supervisor: Brooks More License No: \_\_\_\_\_  
 Supervisor phone: 207-553-7780, X 219 E-mail: \_\_\_\_\_  
 Installing contractor: Bryan Ross/SimplexGrinnell License No: N/A  
 Contractor phone: 207-842-6440, X 220 (Tim) E-mail: thimane@simplexgrinnell.com  
 The suppression work to be done will be: New:  Renovation:  Addition to existing system:   
 This is an amendment to an existing permit: Yes:  NO:  Permit no: \_\_\_\_\_

System Type: Wet chemical kitchen hood system  
 NFPA Standard: 17A + 96 Edition: 2013 + 2014

\*Non-NFPA systems are not approved for use within the City of Portland.

COST OF WORK: \$2,333.00  
 PERMIT FEE: \$60.00  
 (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

Download a new copy of this document from [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Attach all working documents as required on electronic PDF's in addition to full sized plans.

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.  
 Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.  
 All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: [Signature], Tim Hinman Date: January 14, 2015  
SimplexGrinnell