



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road Poland
P.O. Box 154 Minot, ME
Poland, ME 04274
207-998-2551

Job Name : 409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B
Drawing : FP-02
Location : 3rd Floor Unit 316
Remote Area : 3B
Contract : 101513-1
Data File : Calc #3B 3rd floor unit 316.WXF

HYDRAULIC CALCULATIONS
for

Project name: 409 CUMBERLAND AVE APARTMENT COMPLEX
Location: 3rd Floor Unit 316
Drawing no: FP-02
Date: 1-23-14

Design

Remote area number: 3B
Remote area location: 3rd Floor Unit 316
Occupancy classification: Light Hazard/ Residential
Density: .1 - Gpm/SqFt
Area of application: 472 - SqFt
Coverage per sprinkler: 224 - SqFt
Type of sprinklers calculated: quick response residential pendent
No. of sprinklers calculated: 4
In-rack demand: n/a - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 196 - GPM @ 70 - Psi
Type of system: wet system
Volume of dry or preaction system: n/a - Gal

Water supply information

Date: 5-19-05
Location: Corner of Cumberland ave and Mechanic Street
Source: City of Portland

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Pola
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

High Tech Fire Protection
409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B

Page 2
Date 1-23-14

City Water Supply:
C1 - Static Pressure : 79
C2 - Residual Pressure: 76
C2 - Residual Flow : 2094

Demand:
D1 - Elevation : 13.643
D2 - System Flow : 95.942
D2 - System Pressure : 69.426
Hose (Demand) : 100
D3 - System Demand : 195.942
Safety Margin : 9.537



Fittings Used Summary

High Tech Fire Protection
409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B

Page 3
Date 1-23-14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0	
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
 409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B

Page 4
 Date 1-23-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.8	11.42	na	19.6	0.1	196	7.0
DP2	-1.0	5.8	14.92	na	22.4	0.1	224	7.0
300	46.5	K = K @ EQ01	13.89	na	21.56			
301	46.5	K = K @ EQ02	14.94	na	22.4			
302	46.5	K = K @ EQ02	19.01	na	25.27			
303	46.5		19.09	na				
304	46.5	K = K @ EQ02	21.26	na	26.72			
305	46.0		31.48	na				
332	46.0		32.15	na				
352	46.0		34.36	na				
353	46.0		42.25	na				
SA3	46.0		48.18	na				
SA0	8.9		64.42	na				
TOR	8.9		64.62	na				
BOR	3.0		70.23	na				
BASE	0.0		75.81	na				
HS1	10.0		71.51	na				
HS2	12.0		70.68	na				
HS3	12.0		70.68	na	100.0			
TEST	15.0		69.43	na				

The maximum velocity is 20.17 and it occurs in the pipe between nodes 304 and 305

Final Calculations - Hazen-Williams

High Tech Fire Protection
409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B

Page 5
Date 1-23-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	19.60 19.6	1.101 150.0 0.0655	1N	7.0 0.0 0.0	0.500 7.000 7.500	11.420 -0.433 0.491			K Factor = 5.80	
	0.0 19.60						11.478		K Factor = 5.79	
DP2 to EQ02	22.40 22.4	1.101 150.0 0.0838	1O	5.0 0.0 0.0	0.500 5.000 5.500	14.916 -0.433 0.461			K Factor = 5.80	
	0.0 22.40						14.944		K Factor = 5.79	
300 to 301	21.56 21.56	1.101 150.0 0.0782	1N	7.0 0.0 0.0	6.500 7.000 13.500	13.888 0.0 1.056			K Factor @ node EQ01	
									Vel = 7.27	
301 to 303	22.40 43.96	1.101 150.0 0.2921	1O	5.0 0.0 0.0	9.200 5.000 14.200	14.944 0.0 4.148			K Factor @ node EQ02	
	0.0 43.96						19.092		K Factor = 10.06	
302 to 303	25.27 25.27	1.101 150.0 0.1053		0.0 0.0 0.0	0.750 0.0 0.750	19.013 0.0 0.079			K Factor @ node EQ02	
									Vel = 8.52	
303 to 304	43.96 69.23	1.394 150.0 0.2145		0.0 0.0 0.0	10.100 0.0 10.100	19.092 0.0 2.166				Vel = 14.55
304 to 305	26.71 95.94	1.394 150.0 0.3922	1O 1N	6.0 8.0 0.0	11.500 14.000 25.500	21.258 0.217 10.001			K Factor @ node EQ02	
	0.0 95.94						31.476		K Factor = 17.10	
305 to 332	95.94 95.94	2.003 150.0 0.0671		0.0 0.0 0.0	10.000 0.0 10.000	31.476 0.0 0.671				Vel = 9.77
332 to 352	0.0 95.94	2.003 150.0 0.0671		0.0 0.0 0.0	33.000 0.0 33.000	32.147 0.0 2.215				Vel = 9.77
352 to 353	0.0 95.94	2.003 150.0 0.0671	1N 1T	11.0 12.965 0.0	93.500 23.965 117.465	34.362 0.0 7.885				Vel = 9.77
353 to SA3	0.0 95.94	2.157 120.0 0.0707	1B 1Fsp 1S 1T 1V	7.384 0.0 13.537 12.307 4.307	4.000 37.535 41.535	42.247 3.000 2.937			* Fixed loss = 3	Vel = 8.42
SA3 to SA0	0.0 95.94	4.26 120.0 0.0026	3V	26.861 0.0 0.0	36.500 26.861 63.361	48.184 16.068 0.163				Vel = 2.16
SA0 to TOR	0.0 95.94	4.26 120.0 0.0026	3V 1X	26.861 21.067 0.0	31.500 47.928 79.428	64.415 0.0 0.205				Vel = 2.16

Final Calculations - Hazen-Williams

High Tech Fire Protection
 409 CUMBERLAND AVE APARTMENT COMPLEX 3rd FLOOR UNIT 316 3B

Page 6
 Date 1-23-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TOR	0.0	4.26	1B 15.8	4.000	64.620				
to		120.0	1Fsp 0.0	15.800	5.555			* Fixed loss = 3	
BOR	95.94	0.0026	0.0	19.800	0.051			Vel = 2.16	
BOR	0.0	4.26	1Zia 0.0	2.000	70.226				
to		120.0	1E 13.167	39.501	5.478			* Fixed loss = 4.178	
BASE	95.94	0.0026	1T 26.334	41.501	0.106			Vel = 2.16	
BASE	0.0	6.16	1G 4.304	25.000	75.810				
to		140.0	1T 43.037	67.425	-4.331				
HS1	95.94	0.0003	1E 20.084	92.425	0.030			Vel = 1.03	
HS1	0.0	6.16	1T 43.037	80.000	71.509				
to		140.0	0.0	43.037	-0.866				
HS2	95.94	0.0003	0.0	123.037	0.039			Vel = 1.03	
HS2	0.0	12.46	1T 52.745	20.000	70.682				
to		100.0	0.0	52.745	0.0				
HS3	95.94	0.0	0.0	72.745	0.002			Vel = 0.25	
HS3	100.00	6.16	1G 4.304	10.000	70.684			Qa = 100	
to		140.0	1E 20.084	24.388	-1.299				
TEST	195.94	0.0012	0.0	34.388	0.041			Vel = 2.11	
	0.0								
	195.94				69.426			K Factor = 23.52	