

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

AVESTA 409 CUMBERLAND LP /High Tech Fire Protection

Located at

67 FOREST AVE

PERMIT ID: 2014-00726

ISSUE DATE: 06/09/2014

CBL: 036 H019001

has permission to **Fire suppression for a new 4 story apartment building.**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

FP Sprinkler

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-00726	Date Applied For: 04/14/2014	CBL: 036 H019001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: New Apartment Building		Proposed Project Description: Fire suppression for a new 4 story apartment building.		
Dept: Zoning Status: Approved Reviewer: Tammy Munson Approval Date: 04/28/2014		Ok to Issue: <input checked="" type="checkbox"/>		
Note:				
Conditions:				
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 06/09/2014		Ok to Issue: <input checked="" type="checkbox"/>		
Note:				
Conditions:		<ol style="list-style-type: none"> 1) Sprinkler supervision shall be provided in accordance with NFPA 101, Life Safety Code, and NFPA 72, National Fire Alarm and Signaling Code. 2) Fire Department Connections shall be located on the front of the building (address side) and not in a position to block egress once fire hose is connected. 3) System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule. 4) A 4100 series Knox Box is required at the main entrance of the building where the Fire Alarm Control Panel and/or Annunciator is located. 5) Installation shall be in accordance with the City of Portland Fire Department Regulations and NFPA 13 as published. 6) Fire department connection shall be three 2 1/2" inlets unless the riser is 3" or less.(NFPA 1963, Standard For fire Hose Connections.) 7) Installation shall comply with NFPA 14 Standard for the Installation of Standpipe and Hose Systems 8) Shall comply with NFPA 13 Standard for the Installation of Sprinkler Systems. Shall comply with 2009 NFPA 1 Chapter 13 Fire Protection Systems. Pay special attention in the following NFPA 13 Chapters: <ol style="list-style-type: none"> 1.Chapter 6.7.4 Identification of Valves 2.Chapter 7.7.1.5 Signs 3.Chapter 8.17.2.4.7 Signs. 		