

Inspection Services
Michael J. Nugent
Manager



Department of Urban Development
Joseph E. Gray, Jr.
Director

CITY OF PORTLAND

Bubba Larkin
Bubba's Cafe
92 Portland Street
Portland, Maine 04101
CBL:
RE: Electrical violations

February 3, 2000

Recent inspections conducted on 10/26/99 and again on 02/03/00, revealed the following violations and unsafe conditions, **which present a clear and present danger to the building and its occupants, creating severe fire and safety hazards**, shall be corrected.

- Remove all extension cords above the suspended ceilings and install proper wiring methods to serve all equipment as needed.
- The illegal wiring in the kitchen addition shall be removed and reinstalled by a Maine licensed electrical contractor.
- Relocate the water heater, which is in violation of the required working clearances for electrical equipment.
- Open junction boxes, throughout ceilings and bar room areas.
- Open wiring throughout ceilings and bar room areas.
- Open splices throughout ceilings and bar room areas.
- The main electrical room shall be kept clean and free from all storage items.
- Broken switches and receptacles.
- Outside signage and lighting shall be brought up to code compliance with approved methods.