

### City of Portland Health Inspection Report

Page 2 of 2

Establishment Name <u>Geo's Pastisserie Cafe</u>		As Authorized by 22 MRSA § 2496		Date <u>01/26/09</u>
---	--	---------------------------------	--	-------------------------

License/EST. ID #	Address <u>17 Forest Ave</u>	City/State <u>Portland ME</u>	Zip Code	Telephone
-------------------	---------------------------------	----------------------------------	----------	-----------


#### TEMPERATURE OBSERVATIONS

Item/Location	Temp	Item/Location	Temp	Item/Location	Temp
<u>Handsink # 2</u>	<u>110°F</u>	<u>Cooler # 2</u>	<u>38°F</u>	<u>Soup (Hot)</u>	<u>141°F</u>
<u>Handsink # 2</u>	<u>90°F</u>	<u>S cooler # 2</u>	<u>39°F</u>		

#### OBSERVATIONS AND CORRECTIVE ACTIONS

Violations cited in this report must be corrected within the time frames below, or as stated in sections 8-405.11 and 8-406.11 of the Food Code.

Item Number	Violations
<u>49</u>	<u>Plumbing installed per law Handsink in coffee bar area brought up to 110°-120°F (max) 5-20-12</u>
<u>8</u>	<u>Re-mount soup &amp; coffee bar area 6-30-14</u>

Person in Charge (Signature) 	Date <u>01/26/09</u>
Health Inspector (Signature)	Date <u>01/26/09</u>