

Addendum 03

Date: November 17, 2010

To: Wright Ryan Construction (Construction Manager)
From: Ben Walter, CWS Architects
Regarding: **Oak Street Apartments** – Portland, Maine
Subject: **Addendum 03**

Modify the previously issued documents dated October 25, 2010 and any previously issued addenda, if applicable, as follows:

Book 1 -Bidding and Contract Documents Manual:

Book 2 -Specifications Manual:

1. 26000 Electrical – Modify 2.13 FIRE ALARM SYSTEM to add the following in place of the digital alarm communicator transmitter and associated telephone interface hardware: “Contractor shall supply and install radio fire alarm master box manufacturer by AES with antenna per City of Portland Fire Alarm Standards. Exact type of master box shall comply with City of Portland and be installed at the location specified by the Portland Fire Department.”

Drawings:

Title Page

N/A

Civil and Site:

N/A

Structural:

N/A

Architectural:

N/A

Mechanical:

N/A

Electrical:

N/A

End of Addendum 03

Attachments: (See attached specifications, sketches and drawings listed above, if applicable)