DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

PACHIOS BROTHERS I LLC & LACONIA LLC

Located at

565 CONGRESS ST

PERMIT ID: 2016-01149

ISSUE DATE: 07/21/2016

CBL: 037 A038001

has permission to Renovations to Baxter Academy, first floor to provide additional bathrooms and

add 3 small classrooms and 1 conference room

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Michael White

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

1st floor - High School- Baxter Academy

Building Inspections

Type: 2B

Educational - High School with

Accessory Offices

Assembly - Gallery space

Use Group: E/A-3

Occupant Load additional 25 = 208

(139 students & faculty, 69 gallery)

NFPA 13 Sprinkler System 561 Congress, 1st Floor

MUBEC/IBC 2009

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing
Electrical Close-in
Above Ceiling Inspection
Certificate of Occupancy/Final
Final - Electric
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 05/05/2016 2016-01149 037 A038001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Renovations to Baxter Academy, first floor to provide additional Education - Baxter Academy bathrooms and add 3 small classrooms and 1 conference room Reviewer: Robert Wiener **Dept:** Historic **Status:** Approved w/Conditions **Approval Date:** 06/23/2016 Ok to Issue: Note: **Conditions:** 1) No exterior alterations are approved with this permit. If any exterior work is planned, including but not limited to venting, mechanicals, signage, lighting, masonry, windows, doors, etc., it must be reviewed and approved in advance. 05/25/2016 **Dept:** Zoning Status: Approved **Reviewer:** Tammy Munson **Approval Date:** Note: Ok to Issue: **Conditions: Dept:** Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Tammy Munson 07/21/2016 **Approval Date:** Ok to Issue: Note: **Conditions:** 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. **Dept:** Engineering DPS **Status:** Not Applicable Reviewer: Rachel Smith **Approval Date:** 05/13/2016 Ok to Issue: Note: **Conditions:** 1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov Dept: Fire Status: Approved w/Conditions Reviewer: Michael White **Approval Date:** 06/02/2016 Note: See additional comments for new plans forthcoming Ok to Issue: **Conditions:** 1) Application requires State Fire Marshal approval. 2) All means of egress to remain accessible at all times. 3) All construction shall comply with 2009 NFPA 101, Chapter 14 New Educational Occupancies 4) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the

responsibility of compliance with this Code (Chapter 1.14.4).

5) All construction shall comply with City Code, Chapter 10.