LEGEND:

2 HEAD EMERGENCY LIGHT	
EXIT SIGN	EXIT
FIRE EXTINGUISHER	FE
EXISTING WALL	
NEW WALL	

W1 1 HOUR BEARING STAIR WALL

2 1-HOUR BEARING WALL
SCALE: 1 1/2"=1'-0"

W1 1-HOUR BEARING WALL ASSEMBLY
G.A. FILE NO. WP3240
Fire Test: UL R1319-93, 94, 129± UL Des. U311

1. Wood Studs -- Nom 2x with two 2x top and one 2x bottom plates.
2. Wallboard, Gypsum -- 5/8" proprietary type X gypsum wallboard applied parallel to channels with 1 1/4" Type W drywall screws 12" o.c. Vertical joints staggered 48" on opposite sides.

- BUILDING IS FULLY SPRINKLED
- RELOCATING BAR
- NEW WALL AND EGRESS DOOR AS INDICATED

1 PROPOSED FIRST FLOOR PLAN - 2,426 GROSS SQ.FT.
SCALE: 1/4"=1'-0"

5' 4' 3' 2' 1' 0 5' 10'
GRAPHIC SCALE ¼" = 1'-0"

LICENSED ARCHITECT DAVID LLOYD NO. 936 STATE OF MAINE

Inspection Division
Date: 07/16/13

Consulting Engineer:

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
EMPIRE
575 CONGRESS STREET
PORTLAND, MAINE

Revisions:

Scale: 1/4" = 1'-0"

Date: 03 JULY 2013

FIRST FLOOR PLAN MODIFICATIONS

A1