

9/12/16

Scope of Work: 380 Cumberland Ave. Tenant Fit Up

Norris Inc. will add, remove and relocate fire alarm devices as needed to fit up the first floor. The tenant space will be occupied by MECCA. The building has an existing addressable Notifier fire alarm panel which is located on the first floor. The existing panel will accommodate the new devices required for the fit up. The panel is currently monitored by a 24 hour central station (HSMC).