



GENERAL NOTES

- REFRIGERANT LIQUID AND HOT GAS PIPING TO BE RUN ON UNISTRUT FROM STRUCTURAL SLAB ABOVE. SIZE AND INSTALLATION SHALL BE AS RECOMMENDED BY MANUFACTURER.
- DROP PIPING DOWN ALONGSIDE UNIT AND CONNECT TO UNDERSIDE OF CRAC UNIT. REFER TO MANUFACTURER'S LITERATURE FOR CONNECTION LOCATION AND SIZES.
- ELECTRICAL TO PROVIDE 120V POWER TO DDC CONTROL PANELS.
- COORDINATE WITH STRUCTURAL DRAWINGS AND STRUCTURAL ENGINEER FOR ALL WALL, FLOOR, AND ROOF OPENINGS.
- ALL PIPING TO FUTURE UNITS SHALL BE FULLY INSTALLED AND CAPPED FOR FUTURE USE.
- COORDINATE ROUTING AND INSTALLATION OF CONDENSATE DRAIN LINE WITH HUMIDIFIER WATER PIPING. SEE DWG. P101

P:\2001\350100100\Task\HVAC.dwg

0	FOR CONSTRUCTION	7/13/01
no.	revisions/submissions	date

Einhorn Yaffee Prescott ARCHITECTURE & ENGINEERING, P.C.
 700 NORTH FORT STREET, PORTLAND, ME 04108
 PHONE: 603.738.8866
 FAX: 603.738.8866
 1000 WASHINGTON ST., SUITE 200, PORTLAND, ME 04101

CommTel Data Center
 380 Cumberland Avenue
 Portland, Maine

drawing title
HVAC FIRST FLOOR PIPING PLAN

designed by	JML	project no.	5501001.00
drawn by	JML	CAD file no.	P:2000\5501001\HVAC
checked by	WJK	drawing no.	H201
date	07/13/01	scale	1/8"=1'-0"

A1 FIRST FLOOR PIPING PLAN

1/8"=1'-0"

CTL-ABD1