



FOOTING/PIER SCHEDULE			
TYPE	SIZE (W x L)	THICKNESS (T)	REINFORCEMENT
P1	2'-2"x1'-6"	-	(8) #6's EQ SPC
P2	1'-3"x2'-2"	-	(6) #6's EQ SPC
P3	2'-2"x2'-2"	-	(8) #6's EQ SPC
P4	1'-0"x1'-6"	-	(6) #6's EQ SPC
P5	1'-10"x1'-6"	-	(8) #6's EQ SPC
P6	1'-8"x1'-6"	-	(6) #6's EQ SPC
P7	2'-2"x1'-6"	-	(8) #6's EQ SPC
F1	3'-0"x3'-0"	1'-0"	#4's @ 8" MAX E/W
F2	2'-0"x3'-0"	1'-0"	#4's @ 8" MAX E/W
EF1	1'-8"	1'-0"	#5's @ 6" MAX OC
EF2	2'-0"	1'-0"	#5's @ 6" MAX OC
EF3	1'-8"	1'-0"	#5's @ 6" MAX OC

NOTE:  
SEE DTL A10/S401 FOR TIE SIZES.

P:\2001\3501001.00\Tbk\VFfega.grt

0	FOR CONSTRUCTION	7/13/01
no.	revisions/submissions	date



**Einhorn Yaffee Prescott** ARCHITECTURE & ENGINEERING, P.C.  
 THIRTY-FOUR SCHOOL STREET, PORTLAND, ME 04108 87.388-1866  
 AGENCY OF THE STATE OF MAINE, 100 WATER STREET, PORTLAND, ME 04101

**CommTel Data Center**  
 380 Cumberland Avenue  
 Portland, Maine

drawing title

seal	designed by	project no.
	drawn by	CAD file no.
	checked by	drawing no.
	date	
	07/13/01	S101
	scale	1/8"=1'-0"
		of

- NOTES:
- CONTRACTOR SHALL FIELD VERIFY EXISTING RAMP & BUILDING FOOTING CONDITIONS AND CONTACT STRUCTURAL ENGINEER PRIOR TO START OF WORK.
  - CONTRACTOR SHALL EXCAVATE CONTINUOUS FOOTINGS TO BEAR ON BEDROCK (UND).
  - CONTRACTOR SHALL LOCATE LOWEST ELEVATION & EXCAVATE TO THAT DEPTH.



A1 FOUNDATION PLAN

1/8"=1'-0"