



NOTE:
 ALL DRIP PAN LOCATIONS SHALL HAVE A 1-1/4" DRAIN TO INDIRECT WASTE RECEIVER AS INDICATED. ALL DRAIN PANS SHALL BE WATER TIGHT AND TESTED PRIOR TO INSTALLATIONS OF TELCOM & ELECTRICAL EQUIPMENT.

NOTE:
 ALL DRIP PANS TO BE FURNISHED AS PART OF THIS CONTRACT. DRIP PANS SHALL BE ALUMINUM. DRIP PANS SHALL EXTEND TO 8 INCHES OF CENTER LINE ON BOTH SIDES OF PIPE AND BE 2 INCHES DEEP.

P:\2001\5501001.dwg\TitleBlock.dwg

| | | |
|-----|-----------------------|---------|
| 0 | FOR CONSTRUCTION | 7/13/01 |
| no. | revisions/submissions | date |

Einhorn
 Yaffee
 Prescott ARCHITECTURE & ENGINEERING, P.C.
THIRTY-FOUR ROCKS BLVD
 PORTLAND, ME 04106 87.388-8865
 ALBANY, NY
 800 750-8775
 LOS ANGELES, CA
 800 855-8865

Commtel Data Center
 380 Cumberland Avenue
 Portland, Maine

drawing title
PLUMBING FIRST FLOOR PIPING PLAN

| | | | |
|-------------|------------|--------------|---------------------------|
| designed by | JPP | project no. | 5501001.00 |
| drawn by | JPP | CAD file no. | P:\2001\5501001\PLBG\PL01 |
| checked by | DFR | drawing no. | P101 |
| date | 7/13/01 | | |
| scale | 1/8"=1'-0" | | |