

SYSTEM RECORD OF COMPLETION

Form Completion Date: 10-28-16

Supplemental Pages Attached: 1

1. PROPERTY INFORMATION

Name of property: 380 Cumberland Ave 1st Floor Renovation Only

Address: 380 Cumberland Avenue Portland Maine

Description of property: Office building

Name of property representative: AM Partners

Address: 120 Exchange Street Portland Maine

Phone: 207-879-1358

Fax: _____

E-mail: _____

2. INSTALLATION, SERVICE, TESTING, AND MONITORING INFORMATION

Installation contractor: Norris Inc

Address: 2257 West Broadway South Portland Maine

Phone: 207-883-3473

Fax: _____

E-mail: _____

Service organization: Norris Inc

Address: 2257 West Broadway South Portland Maine

Phone: 207-883-3473

Fax: _____

E-mail: _____

Testing organization: _____

Address: _____

Phone: _____

Fax: _____

E-mail: _____

Effective date for test and inspection contract: _____

Monitoring organization: HSMC

Address: 57 Central Drive Stowe Vermont

Phone: 1800-933-4762

Fax: _____

E-mail: _____

Account number: 2028549

Phone line 1: _____

Phone line 2: _____

Means of transmission: Digital

Entity to which alarms are retransmitted: Portland FD

Phone: 207-874-8576

3. DOCUMENTATION

On-site location of the required record documents and site-specific software: at FACF

4. DESCRIPTION OF SYSTEM OR SERVICE

This is a: New system Modification to existing system Permit number: _____

NFPA 72 edition: _____

4.1 Control Unit

Manufacturer: Notifier

Model number: NFS-320

4.2 Software and Firmware

Firmware revision number: 24

4.3 Alarm Verification

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: _____ Alarm verification set for _____ seconds

SYSTEM RECORD OF COMPLETION (continued)

5. SYSTEM POWER

5.1 Control Unit

5.1.1 Primary Power

Input voltage of control panel: 120VAC Control panel amps: _____
 Overcurrent protection: Type: Circuit Breaker Amps: 20
 Branch circuit disconnecting means location: LP1 Number: 42

5.1.2 Secondary Power

Type of secondary power: n/a
 Location, if remote from the plant: _____
 Calculated capacity of secondary power to drive the system: _____
 In standby mode (hours): _____ In alarm mode (minutes): _____

5.2 Control Unit

- This system does not have power extender panels
- Power extender panels are listed on supplementary sheet A

6. CIRCUITS AND PATHWAYS

Pathway Type	Dual Media Pathway	Separate Pathway	Class	Survivability Level
Signaling Line			B	4
Device Power				
Initiating Device				
Notification Appliance			B	4
Other (specify):				

7. REMOTE ANNUNCIATORS

Type	Location
Nann-80	Main Entry

8. INITIATING DEVICES

Type	Quantity	Addressable or Conventional	Alarm or Supervisory	Sensing Technology
Manual Pull Stations	4	Addressable	Alarm	
Smoke Detectors	11	Addressable	Alarm	Photo
Duct Smoke Detectors				
Heat Detectors	22	Addressable	Alarm	Fixed 135
Gas Detectors				
Waterflow Switches	1	Addressable	Alarm	
Tamper Switches				

