



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

2/12/14

Scope of Work: 537 Congress St.

DL Electric will be installing fire alarm devices on the 3rd floor to accommodate the addition of 9 new apartment units. A speaker strobe will be installed in the common area and bedrooms of each unit. The existing fire alarm system is an addressable Notifier panel with voice evacuation which can be expanded to accommodate the new addition. This permit is for the apt. side of the 3rd floor only. The office side of the floor will remain as is.

Norris Inc. will provide and install the fire alarm equipment, provide the required documentation for fire alarm permits, final connections and testing according to City of Portland requirements.

The existing system is currently monitored by a 24 hour central station. As part of this renovation, Norris Inc. will be installing a new AES Radio Master box for the building per fire dept. request.