

3 to 12.5 Ton Side Duct Dimensions

Unit Model Number	Dimension (in.)			
	A	B	C	D
ZS -06, -07	27 3/4	12 1/16	27 1/2	16
ZS-08, -10	28 1/4	18 1/16	28 1/4	18 1/4
ZS-12	28 1/4	18 1/16	28 1/4	18 1/4
ZU-A3, -A4, -A5, -06, -07	27 3/4	12 1/16	27 1/2	16
ZU-08, -10	28 1/4	18 1/16	28 1/4	18 1/4
ZU-12	28 1/4	18 1/16	28 1/4	18 1/4
ZW-A3, -A4, -A5	27 3/4	12 1/16	27 1/2	16
ZW-06, -07, -08, -10	28 1/4	18 1/16	28 1/4	18 1/4
ZW-12	28 1/4	18 1/16	28 1/4	18 1/4
ZK-A3, -A4, -A5	27 3/4	12 1/16	27 1/2	16
ZK-06, -07	27 3/4	12 1/16	27 1/2	16
ZK-08, -10	28 1/4	18 1/16	28 1/4	18 1/4
ZK-12	28 1/4	18 1/16	28 1/4	18 1/4

3 to 12.5 Ton Unit Clearances

Direction	Distance (in.)	Direction	Distance (in.)
Top ¹	72	Right	12
Front	36	Left	36
Rear	36	Bottom ²	0

1. Units must be installed outdoors. Over hanging structure or shrubs should not obscure condenser air discharge outlet.
2. Units may be installed on combustible floors made from wood or class A, B or C roof covering materials.