SUBMITTAL DATA SHEET

SINGLE PACKAGE AIR CONDITIONERS AND GAS/ELECTRIC HEAT UNITS, 3 THROUGH 12-1/2 TONS
MODELS: ZU/ZW/ZK-A3 to -12, ZS-06 to -12

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/14/13

Planner: Tammy Munson

JOB NAME: CPS Property LOCATION: 572 Congress.

PURCHASER: Thomas Molitern. ORDER NO:

ENGINEER:

SUBMITTED TO: FOR: REF: APPROVAL: CONSTRUCTION:

SUBMITTED BY: DATE:

UNIT DESIGNATION: SCHEDULE NO. MODEL NO. 6.5 TON

M/N# York ZS-06N18ATAAAS- 6.5-

3

COOLING PERFORMANCE

TOTAL CAPACITY ---------- ____ MBH

SENSIBLE CAPACITY ---------- ____ MBH

OUTDOOR DESIGN TMP. _____ °F DB/WB

TOTAL SUPPLY AIR ---------- ____ CFM

TEMP. OF AIR ENTERING EVAPORATOR COIL ---------- ____ °F

POWER INPUT REQ. ---------- ____ KW (LESS BLOWER MOTOR)

HEATING PERFORMANCE

ELECTRIC HEAT ---------- ____ KW

GAS-FIRED INPUT CAP. ---------- ____ MBH

SUPPLY AIR BLOWER PERFORMANCE

TOTAL SUPPLY AIR ---------- ____ CFM

EXT. STATIC PRESS. ---------- ____ IWG

BLOWER SPEED ---------- ____ RPM

POWER OUTPUT REQ. ---------- ____ BHP

MOTOR RATING ---------- ____ HP

POWER INPUT REQ. ---------- ____ KW

ELECTRICAL DATA

POWER SUPPLY ---------- _____

TOTAL UNIT AMPACITY -------- ____ AMPS

MAX. OVERCURRENT DEVICE
__ FUSE __ BREAKER --------- ____ AMPS

TOTAL UNIT WEIGHT

INCLUDING FACTORY- INSTALLED OPTIONS ---------- ____ LBS