



PORTLAND MAINE

Strengthening a Remarkable City. Building a Community for Life • www.portlandmaine.gov

Lee Urban - Director of Planning and Development
Jeanie Bourke - Inspection Division Services Director

Kitchen Exhaust System Checklist and code Provisions

Dear Applicant,

The following is a checklist to assist you in filing for a permit for a Kitchen Exhaust system. The applicable Mechanical Code provisions have also been attached. Please complete this and submit job specific construction documents that demonstrate compliance with the attached information.

Type of System:

Type I X Type II _____

Type I systems are systems that vent fryers, grills, broilers, ovens or woks.

Type II systems are systems that vent steamers and other non grease producing appliances.

Type of Materials:

Is the hood Stainless steel or other type of steel? _____ If Other, what Type? Stainless/galv painted

Is the duct work Stainless steel or other type of steel? other If Other, what type? 16ga galv an steel

Thickness of the steel for the hood 16 gauge

Thickness of the duct for the hood 16 gauge

Type of Hood and Duct Supports

3/8 THREADED ROD INTO ROOF TRUSS

Type of seams and Joints Solid welded seam Hood to fan