

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 101 Congress St (Older Plaza)		Owner: The Portland Land Trust		Phone: 708-1-1111		Permit No: 951058	
Owner Address:		Leasee/Buyer's Name:		Phone:		Business Name:	
Contractor Name: Portland Building Systems, Inc.		Address: 4 Overton St. Portland, ME 04103		Phone: 708-1-1111		<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED PERMIT ISSUED: OCT - 6 1995 CITY OF PORTLAND </div>	
Past Use: Office Bldg.		Proposed Use: Office		COST OF WORK: \$ 10,000.00 PERMIT FEE: \$ 1,000.00		INSPECTION: Use Group: Type:	
Proposed Project Description: Install sprinkler system		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied Signature: [Signature]		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zone: CBL:	
						Zoning Approval:	
						Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: [Signature]		Date Applied For: 08/01/95					

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Zoning Appeal

☐ Variance
☐ Miscellaneous
☐ Conditional Use
☐ Interpretation
☐ Approved
☐ Denied

Historic Preservation

☐ Not in District or Landmark
☒ Does Not Require Review
☐ Requires Review

Action:

☐ Approved
☐ Approved with Conditions
☐ Denied

Date: _____

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: [Signature] ADDRESS: _____ DATE: _____ PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT

WING



PERMIT ISSUED
WITH REQUIREMENTS

SPRINKLER SYSTEMS INC.
P.O. BOX 1285 - LEWISTON, MAINE 04243-1285

memo

LETTER

(207) 782-0104

To City of Portland
Code enforcement

Date 10/4/95

Subject 511 Congress St
8th & 9th floors

— TRANSMITTAL —

2 - 1 of 1 Shop Drawings
2 - sets of 8th floor CALCS
2 - sets of 9th floor CALCS
2 - sets of standpipe CALCS
1 - check for \$70.00

* Permit

☐ Please reply

☐ No reply necessary

SIGNED

Clayton Sauer
Clayton Sauer

BUILDING PERMIT REPORT

DATE

10/5/95

ADDRESS

561 Congress St

REASON FOR PERMIT

Sprinkler Installation

BUILDING OWNER

October Corp

CONTRACTOR

Sprinkler Systems Inc

PERMIT APPLICANT

Scott G. G. /


APPROVED

✓

DENIED

CONDITIONS OF APPROVAL:

1. A 4" storz fire department connection is required.
2. Any new sprinkler construction over 6 sprinkler heads needs to have State Fire Marshall approval.
3. Any renovations of sprinkler systems over 20 sprinkler heads needs to have State Fire Marshall approval.
4. A sprinkler performance test shall be submitted to the Portland Fire Department after completion of sprinkler work.



[\\/]\\]
[\\/]\\]

...FIRE PROTECTION BY COMPUTER DESIGN

```

*****
*      SPRINKLER SYSTEMS INC.      *
*      LEWISTON, ME  04240         *
*      207-782-0104                *
*****

```

```

*****
* CONTRACTOR      SPRINKLER SYSTEMS INC.      *
* NAME            511 CONGRESS ST.  8TH FLOOR  *
* LOCATION        511 CONGRESS STREET,  PORTLAND,  MAINE  *
* SYSTEM NO.      1                               *
* CONTRACT NO.    95044                          *
*****

```

SPRINKLER SYSTEMS INC.

LEWISTON, ME 04240

207-782-0104

HYDRAULIC DESIGN INFORMATION SHEET

NAME 511 CONGRESS ST. STANDPIPE DATE 10/04/95
 LOCATION 511 CONGRESS STREET, PORTLAND, MAINE
 BUILDING EXISTING SYSTEM NO. EX.STPIPE
 CONTRACTOR SPRINKLER SYSTEMS INC. CONTRACT NO. 95044
 CALCULATED BY CDS DRAWING NO. 1-1 OF 1
 CONSTRUCTION: () COMBUSTIBLE (X) NON-COMBUSTIBLE CEILING HEIGHT
 OCCUPANCY OFFICES

S ! () NFPA 13 () LT. HAZ. ORD. HAZ. GP. () 1 () 2 () 3 () EX. HAZ.
 Y ! () NFPA 231 () NFPA 231C FIGURE 2-2.1.1B CURVE
 S ! (X) OTHER N.F.P.A. 14
 T ! () SPECIFIC RULING MADE BY DATE
 E !

M ! AREA OF SPRINKLER OPERATION 0 SYSTEM TYPE
 ! DENSITY- GPM 0 (X) WET () DRY () DELUGE () PREACTION
 D ! AREA PER SPRINKLER 0 SPRINKLER OR NOZZLE
 E ! HOSE ALLOWANCE GPM-INSIDE 500 MAKE MODEL
 S ! HOSE ALLOWANCE GPM-OUTSIDE 0 SIZE K-FACTOR 0
 I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING
 G !
 N !

CALCULATION ! GPM REQUIRED 500 PSI REQUIRED 148.94 AT BASE OF RISER
 SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 140

W ! WATER FLOW TEST SEE PUMP TEST RESULTS ON PLAN ! PUMP DATA ! TANK OR RESERVOIR
 A ! DATE OF TEST 10/4/95 ! RATED CAP 500 ! CAP. 0
 T ! TIME OF TEST ! AT PSI 90 ! ELEV. 0
 E ! STATIC (PSI) 0 ! ELEV 0 !
 R ! RESIDUAL (PSI) 0 ! WELL
 ! FLOW (GPM) 0 ! PROOF FLOW GPM 0
 S ! ELEVATION PUMP DISCHARGE !
 U !
 P !

P ! LOCATION : 6" IN STREET
 L ! SOURCE OF INFORMATION : S.S.I. AND PORTLAND WATER DISTRICT
 Y !

! COMMODITY CLASS LOCATION
 C ! STORAGE HT. AREA AISLE WIDTH
 O ! STORAGE METHOD: SOLID PILED % PALLETIZED % RACK %
 M !
 M ! () SINGLE ROW () CONVEN. PALLET () AUTO. STORAGE () ENCAP.
 ! R ! () DOUBLE ROW () SLAVE PALLET () SOLID SHELVING () NON-ENCAP
 S ! A ! () MULTIPLE ROW () OPEN SHELVING
 T ! C !
 O ! K ! FLUE SPACING: CLEARANCE: STORAGE TO CEILING
 R ! LONGITUDINAL TRANSVERSE
 A !
 G ! HORIZONTAL BARRIERS PROVIDED:
 E !

UNITS - DIAMETER (INCH) LENGTH (FOOT) FLOW (GPM) PRESSURE (PSI)

FIRE PROTECTION--BY COMPUTER DESIGN

HYDRLC. REF. POINT	QA FLOW QT	"C" DIA. LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV FN	***** NOTES *****
HV1	500.00	2.469 C=120		0.50 31.00	65.00 0.00		QA= 500.0 PT= 65.00 VELOCITY = 33.49
	500.00	0.7765	31.00F.	31.50	24.46		
A	0.00	6.065 C=120		12.00 0.00	89.46 0.00		QA= 0.0 PT= 89.46 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
B	0.00	6.065 C=120		12.00 0.00	89.58 0.00		QA= 0.0 PT= 89.58 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
C	0.00	6.065 C=120		12.00 0.00	89.70 0.00		QA= 0.0 PT= 89.70 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
D	0.00	6.065 C=120		12.00 0.00	89.82 0.00		QA= 0.0 PT= 89.82 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
E	0.00	6.065 C=120		12.00 0.00	89.94 0.00		QA= 0.0 PT= 89.94 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
F	0.00	6.065 C=120		12.00 0.00	90.06 0.00		QA= 0.0 PT= 90.06 VELOCITY = 5.55
	500.00	0.0097		12.00	0.12		
G	0.00	6.065 C=120	4E14.0	24.00 56.00	90.18 0.00		QA= 0.0 PT= 90.18 VELOCITY = 5.55
	500.00	0.0097		80.00	0.78		
H	0.00	6.065 C=120	4E14.0 1T30.0	26.00 86.00	90.96 0.00		QA= 0.0 PT= 90.96 VELOCITY = 5.55
	500.00	0.0097		112.00	1.09		
I	0.00	6.065 C=120	2E14.0	29.00 28.00	92.05 0.00		QA= 0.0 PT= 92.05 VELOCITY = 5.55
	500.00	0.0097		57.00	0.56		
J	0.00	6.065 C=120	1E14.0 1T30.0	17.00 44.00	92.61 0.00		QA= 0.0 PT= 92.61 VELOCITY = 5.55
	500.00	0.0097		61.00	0.60		
K	0.00	6.065 C=120	1E14.0	5.00 49.00	93.21 0.00		QA= 0.0 PT= 93.21 VELOCITY = 5.55
	500.00	0.0097	35.00F.	54.00	0.53		
100	0.00	3.065 C=120		0.75 0.00	93.74 55.00		QA= 0.0 PT= 93.74 VELOCITY = 21.73
	500.00	0.2709		0.75	0.20		PE= FOR HT. OF 126.9

***** SPRINKLER SYSTEMS INC. *****
JOB- 511 CONGRESS ST. STANDPIPE JOB NO 95044 DATE 10/04/95 PAGE 3
*****EXISTING STANDPIPE CALC.*****

=====

HYDRLC.	QA	DIA.	EQUIV.	PIPE	PT	PT	
REF.	FLOW	"C"	FITTING	FTGS.	PE	PV	***** NOTES *****
POINT	QT	LOSS/F	LENGTHS	TOT.	PF	PN	

=====

	500.00				148.94		K 33= 40.970
PUMP							

SPRINKLER SYSTEMS INC.

LEWISTON, ME 04240
207-782-0104

HYDRAULIC DESIGN INFORMATION SHEET

NAME 511 CONGRESS ST. 9TH FLOOR DATE 10/04/95
LOCATION 511 CONGRESS STREET, PORTLAND, MAINE
BUILDING EXISTING
CONTRACTOR SPRINKLER SYSTEMS INC. SYSTEM NO. 1
CALCULATED BY CDS CONTRACT NO. 95044
CONSTRUCTION: () COMBUSTIBLE (X) NON-COMBUSTIBLE DRAWING NO. 1-1 OF 1
OCCUPANCY OFFICES CEILING HEIGHT

S ! (X) NFPA 13 (X) LT. HAZ. ORD. HAZ. GP. () 1 () 2 () 3 () EX. HAZ.
Y ! () NFPA 231 () NFPA 231C FIGURE 2-2.1.1B CURVE
S ! () OTHER
T ! () SPECIFIC RULING MADE BY DATE
E !
M ! AREA OF SPRINKLER OPERATION 1500 SYSTEM TYPE
! DENSITY- GPM .1 (X) WET () DRY () DELUGE () PREACTION
D ! AREA PER SPRINKLER 225 SPRINKLER OR NOZZLE
E ! HOSE ALLOWANCE GPM-INSIDE 0 MAKE RELIABLE MODEL "G"
S ! HOSE ALLOWANCE GPM-OUTSIDE 100 SIZE 1/2" K-FACTOR 5.62
I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING 165
G !
N !

CALCULATION ! GPM REQUIRED 346.75 PSI REQUIRED 149.26 AT BASE OF RISER
SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 140

W ! WATER FLOW TEST ^{SEE PUMP TEST} _{RESULTS ON PLAN 10f} ! PUMP DATA ! TANK OR RESERVOIR
A ! DATE OF TEST ! RATED CAP 500 ! CAP. 0
T ! TIME OF TEST ! AT PSI 90 ! ELEV. 0
E ! STATIC (PSI) 0 ! ELEV 0 !
R ! RESIDUAL (PSI) 0 ! WELL
! FLOW (GPM) 0 ! PROOF FLOW GPM 0
S ! ELEVATION PUMP DISCHARGE !

U !
P !
P ! LOCATION : 6" IN STREET
L ! SOURCE OF INFORMATION : S.S.I. AND PORTLAND WATER DISTRICT
Y !

! COMMODITY CLASS LOCATION
C ! STORAGE HT. AREA AISLE WIDTH
O ! STORAGE METHOD: SOLID FILED % PALLETIZED % RACK %
M !
M ! () SINGLE ROW () CONVEN. PALLET () AUTO. STORAGE () ENCAP.
! R ! () DOUBLE ROW () SLAVE PALLET () SOLID SHELVING () NON-ENCAP
S ! A ! () MULTIPLE ROW () OPEN SHELVING
T ! C !
O ! K ! FLUE SPACING: CLEARANCE: STORAGE TO CEILING
R ! LONGITUDINAL TRANSVERSE
A !
G ! HORIZONTAL BARRIERS PROVIDED:
E !

UNITS - DIAMETER (INCH) LENGTH (FOOT) FLOW (GPM) PRESSURE (PSI)

FIRE PROTECTION--BY COMPUTER DESIGN

***** SPRINKLER SYSTEMS INC. *****							
JOB- 511 CONGRESS ST. 9TH FLOOR			JOB NO 95044		DATE 10/04/95 PAGE 2		
*****.10/1500+100---MOST REMOTE*****							
=====							
HYDRLC. REF. POINT	QA FLOW QT	"C" DIA. LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
=====							
TYP	22.50	1.049	OE 2.0	1.00	16.03		Q=K*SQR(P) :P= 16.03
		C=120	1T 5.0	5.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		6.00	0.97		

DROP	22.50				17.00		K 23= 5.460

1-1	22.51	1.049	OE 2.0	0.50	17.00		Q=K*SQR(P) :P= 17
		C=120	1T 5.0	5.00	0.00		K= 5.460 V = 8.35
	22.51	0.1619		5.50	0.89		

1	22.51				17.89		K 24= 5.320

ARM	22.50	1.049	1E 2.0	2.50	16.03		Q=K*SQR(P) :P= 16.03
		C=120	1T 5.0	7.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		9.50	1.54		

2-4	22.50				17.57		K 25= 5.370

2-1	22.99	1.049	1E 2.0	11.00	16.74		Q=K*SQR(P) :P= 16.74
		C=120		2.00	0.00		K= 5.620 V = 8.53
	22.99	0.1683		13.00	2.19		

2-2	22.51	1.049		7.50	18.93	18.93	K= 5.460 P= 17.00
		C=120		0.00	0.00	1.93	VELOCITY = 16.88
	45.50	0.5953		7.50	4.47	17.00	

2-3	25.68	1.452	2E 4.0	13.00	23.40	23.40	K= 5.460 P= 22.12
		C=120		8.00	0.00	1.28	VELOCITY = 13.78
	71.18	0.2797		21.00	5.87	22.12	

2-4	27.79	1.452	OE 4.0	15.00	29.27	29.27	K= 5.370 P= 26.79
		C=120	1T 8.0	8.00	0.00	2.48	VELOCITY = 19.16
	98.97	0.5147		23.00	11.84	26.79	

2	98.97				41.11		K 26= 15.440

3-1	22.50	1.049	2E 2.0	15.50	16.03		Q=K*SQR(P) :P= 16.03
		C=120		4.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		19.50	3.16		

3-2	22.70	1.049		14.00	19.19	19.19	K= 5.460 P= 17.29
		C=120		0.00	0.00	1.90	VELOCITY = 16.77
	45.20	0.5881		14.00	8.23	17.29	
=====							

***** SPRINKLER SYSTEMS INC. *****
 JOB- 511 CONGRESS ST. 9TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 3
 *****.10/1500+100---MOST REMOTE*****

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
3-3	26.01 71.21	1.049 C=120 1.3635		12.50 0.00 12.50	27.42 0.00 17.04	27.42 4.72 22.70	K= 5.460 P= 22.70 VELOCITY = 26.42
3-4	35.21 106.42	1.452 C=120 0.5886	OE 4.0 1T 8.0	1.50 8.00 9.50	44.46 0.00 5.59	44.46 2.87 41.59	K= 5.460 P= 41.59 VELOCITY = 20.61
3	106.42				50.05		K 27= 15.040
ARM	22.50 22.50	1.049 C=120 0.1618	1E 2.0 1T 5.0	1.50 7.00 8.50	16.03 0.00 1.38		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
4-1	22.50				17.41		K 28= 5.390
4-1	22.50 22.50	1.049 C=120 0.1618		12.00 0.00 12.00	17.42 0.00 1.94		Q=K*SQR(P):P= 17.42 K= 5.390 V = 8.35
4-2	22.81 45.31	1.049 C=120 0.5907		12.00 0.00 12.00	19.36 0.00 7.09	19.36 1.91 17.45	K= 5.460 P= 17.45 VELOCITY = 16.81
4-3	27.36 72.67	1.452 C=120 0.2906	OE 4.0 1T 8.0	4.00 8.00 12.00	26.45 0.00 3.49	26.45 1.34 25.11	K= 5.460 P= 25.11 VELOCITY = 14.07
4	72.67				29.94		K 29= 13.280
1	37.64 37.64	2.635 C=120 0.0047		2.50 0.00 2.50	50.07 0.00 0.01		Q=K*SQR(P):P= 50.07 K= 5.320 V = 2.21
2	108.72 146.36	2.635 C=120 0.0582	2E 6.0	13.00 12.00 25.00	50.08 0.00 1.46	50.08 0.50 49.58	K= 15.440 P= 49.58 VELOCITY = 8.60
3	106.40 252.76	2.635 C=120 0.1601		8.50 0.00 8.50	51.54 0.00 1.36	51.54 1.49 50.05	K= 15.040 P= 50.05 VELOCITY = 14.86
4	93.99 346.75	2.635 C=120 0.2873	OE 6.0 1T12.0 12.00F.	52.50 24.00 76.50	52.90 0.00 21.99	52.90 2.81 50.09	K= 13.280 P= 50.09 VELOCITY = 20.39

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
6	346.75				74.89		K 30= 40.070
6	346.75	2.635 C=120	1E 6.0	22.50 6.00	74.89 0.00		QA= 346.7 PT= 74.89 VELOCITY = 20.39
	346.75	0.2873		28.50	8.19		
7	0.00	3.068 C=120	2E 7.0 2T15.0	12.00 46.00	83.08 0.00		QA= 0.0 PT= 83.08 VELOCITY = 15.04
	346.75	0.1369	2.00F.	58.00	7.95		
8	0.00	4.026 C=120	0E10.0 1T20.0	5.00 24.00	91.03 0.00		QA= 0.0 PT= 91.03 VELOCITY = 8.73
	346.75	0.0364	4.00F.	29.00	1.06		
A	346.75				92.09		K 31= 36.130
A	346.75	6.065 C=120		12.00 0.00	92.09 0.00		QA= 346.7 PT= 92.09 VELOCITY = 3.85
	346.75	0.0049		12.00	0.06		
B	0.00	6.065 C=120		12.00 0.00	92.15 0.00		QA= 0.0 PT= 92.15 VELOCITY = 3.84
	346.75	0.0049		12.00	0.06		
C	0.00	6.065 C=120		12.00 0.00	92.21 0.00		QA= 0.0 PT= 92.21 VELOCITY = 3.84
	346.75	0.0049		12.00	0.06		
D	0.00	6.065 C=120		12.00 0.00	92.27 0.00		QA= 0.0 PT= 92.27 VELOCITY = 3.84
	346.75	0.0049		12.00	0.06		
E	0.00	6.065 C=120		12.00 0.00	92.33 0.00		QA= 0.0 PT= 92.33 VELOCITY = 3.84
	346.75	0.0049		12.00	0.06		
F	0.00	6.065 C=120		12.00 0.00	92.39 0.00		QA= 0.0 PT= 92.39 VELOCITY = 3.84
	346.75	0.0049		12.00	0.06		
G	0.00	6.065 C=120	4E14.0	24.00 56.00	92.45 0.00		QA= 0.0 PT= 92.45 VELOCITY = 3.84
	346.75	0.0049		80.00	0.40		
H	0.00	6.065 C=120	4E14.0 1T30.0	26.00 86.00	92.85 0.00		QA= 0.0 PT= 92.85 VELOCITY = 3.84
	346.75	0.0049		112.00	0.56		

***** SPRINKLER SYSTEMS INC. *****
 JOB- 511 CONGRESS ST. 9TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 5
 *****.10/1500+100---MOST REMOTE*****

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
I	0.00 346.75	6.065 C=120 0.0049	2E14.0	29.00 28.00 57.00	93.41 0.00 0.28		QA= 0.0 FT= 93.41 VELOCITY = 3.84
J	0.00 346.75	6.065 C=120 0.0049	1E14.0 1T30.0	17.00 44.00 61.00	93.69 0.00 0.30		QA= 0.0 FT= 93.69 VELOCITY = 3.84
K	0.00 346.75	6.065 C=120 0.0049	1E14.0 35.00F.	5.00 49.00 54.00	93.99 0.00 0.27		QA= 0.0 FT= 93.99 VELOCITY = 3.84
100	0.00 346.75	3.065 C=120 0.1376		0.75 0.00 0.75	94.26 0.00 0.10		QA= 0.0 FT= 94.26 VELOCITY = 15.07
PUMP	100.00 446.75	6.065 C=120 0.0079		0.00 0.00 0.00	94.36 55.00 0.00		QA= 100.0 FT= 94.36 VELOCITY = 4.95 PE= FOR HT. OF 126.9
HOSE	446.75				149.36		K 32= 36.560

HYDRLC. REF. POINT	QA FLOW QT	"C" DIA. LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
5-1	22.50	1.049 C=120	1E 2.0 1T 5.0	6.00 7.00	16.03 0.00		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
	22.50	0.1618		13.00	2.10		
5A	22.50				18.13		K 34= 5.280
5-2	22.50	1.049 C=120	1E 2.0 1T 5.0	3.50 7.00	16.03 0.00		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
	22.50	0.1618		10.50	1.70		
5A	22.50				17.73		K 35= 5.340
ARM	22.50	1.049 C=120	1E 2.0 1T 5.0	6.00 7.00	16.03 0.00		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
	22.50	0.1618		13.00	2.10		
5-3	22.50				18.13		K 36= 5.280
ARM	22.50	1.049 C=120	1E 2.0 1T 5.0	2.00 7.00	16.03 0.00		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
	22.50	0.1618		9.00	1.46		
5-4	22.50				17.49		K 37= 5.380
5A	45.22	1.049 C=120		8.00 0.00	18.13 0.00		Q=K*SQR(P):P= 18.13 K= 10.620 V = 16.78
	45.22	0.5886		8.00	4.71		
5-3	24.54	1.452 C=120		6.00 0.00	22.84 0.00	22.84	K= 5.280 P= 21.61 VELOCITY = 13.51
	69.76	0.2694		6.00	1.62	21.61	
5-4	25.33	1.452 C=120	2E 4.0	14.00 8.00	24.46 0.00	24.46	K= 5.380 P= 22.17 VELOCITY = 18.41
	95.09	0.4779		22.00	10.52	22.17	
5-5	31.25	1.687 C=120		12.00 0.00	34.98 0.00	34.98	K= 5.460 P= 32.76 VELOCITY = 18.12
	126.34	0.3894		12.00	4.67	32.76	
5-6	32.82	1.687 C=120	0E 4.0 1T 8.0	4.00 8.00	39.65 0.00	39.65	K= 5.460 P= 36.13 VELOCITY = 22.83
	159.16	0.5970		12.00	7.16	36.13	

***** SPRINKLER SYSTEMS INC. *****
JOB- 511 CONGRESS ST. 9TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 7
*****CHECK LINE 1*****

HYDRLC.	QA	DIA.	EQUIV.	PIPE	PT	PT	
REF.	FLOW	"C"	FITTING	FTGS.	PE	FV	***** NOTES *****
POINT	QT	LOSS/F	LENGTHS	TOT.	PF	PN	
	159.16				46.81		K 38= 23.260
5							

SPRINKLER SYSTEMS INC.

LEWISTON, ME 04240

207-782-0104

HYDRAULIC DESIGN INFORMATION SHEET

NAME 511 CONGRESS ST. 8TH FLOOR DATE 10/04/95
 LOCATION 511 CONGRESS STREET, PORTLAND, MAINE
 BUILDING EXISTING SYSTEM NO. 1
 CONTRACTOR SPRINKLER SYSTEMS INC. CONTRACT NO. 95044
 CALCULATED BY CDS DRAWING NO. 1-1 OF 1
 CONSTRUCTION: () COMBUSTIBLE (X) NON-COMBUSTIBLE CEILING HEIGHT
 OCCUPANCY OFFICES

S ! (X) NFPA 13 (X) LT. HAZ. ORD. HAZ. GP. () 1 () 2 () 3 () EX. HAZ.
 Y ! () NFPA 231 () NFPA 231C FIGURE 2-2.1.1B CURVE
 S ! () OTHER
 T ! () SPECIFIC RULING MADE BY DATE
 E !
 M ! AREA OF SPRINKLER OPERATION 1500 SYSTEM TYPE
 ! DENSITY- GPM .1 (X) WET () DRY () DELUGE () PREACTION
 D ! AREA PER SPRINKLER 225 SPRINKLER OR NOZZLE
 E ! HOSE ALLOWANCE GPM-INSIDE 0 MAKE RELIABLE MODEL "G"
 S ! HOSE ALLOWANCE GPM-OUTSIDE 100 SIZE 1/2" K-FACTOR 5.62
 I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING 165
 G !
 N !

CALCULATION ! GPM REQUIRED 376.66 PSI REQUIRED 142.98 AT BASE OF RISER
 SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 140

W ! WATER FLOW TEST SEE PUMP TEST ! PUMP DATA ! TANK OR RESERVOIR
 A ! DATE OF TEST RESULTS ON PLAN 1041 ! RATED CAP 500 ! CAP. 0
 T ! TIME OF TEST ! AT PSI 90 ! ELEV. 0
 E ! STATIC (PSI) 0 ! ELEV 0 !
 R ! RESIDUAL (PSI) 0 ! WELL
 ! FLOW (GPM) 0 ! PROOF FLOW GPM 0
 S ! ELEVATION PUMP DISCHARGE !
 U !
 P !

P ! LOCATION : 6" IN STREET
 L ! SOURCE OF INFORMATION : S.S.I. AND PORTLAND WATER DISTRICT
 Y !

! COMMODITY CLASS LOCATION
 C ! STORAGE HT. AREA AISLE WIDTH
 O ! STORAGE METHOD: SOLID PILED % PALLETIZED % RACK %
 M !
 M ! () SINGLE ROW () CONVEN. PALLET () AUTO. STORAGE () ENCAP.
 ! R ! () DOUBLE ROW () SLAVE PALLET () SOLID SHELVING () NON-ENCAP
 S ! A ! () MULTIPLE ROW () OPEN SHELVING
 T ! C !
 O ! K ! FLUE SPACING: CLEARANCE: STORAGE TO CEILING
 R ! LONGITUDINAL TRANSVERSE
 A !
 G ! HORIZONTAL BARRIERS PROVIDED:
 E !

UNITS - DIAMETER (INCH) LENGTH (FOOT) FLOW (GPM) PRESSURE (PSI)

FIRE PROTECTION--BY COMPUTER DESIGN

***** SPRINKLER SYSTEMS INC. *****
 JOB- 511 CONGRESS ST. 8TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 2
 *****AREA 1--.10/1500+100*****

HYDRLC. REF. POINT	QA FLOW QT	"C" DIA. LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
TYP	22.50	1.049	OE 2.0	1.00	16.03		Q=K*SQR(P):P= 16.03
		C=120	1T 5.0	5.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		6.00	0.97		
DROP	22.50				17.00		K 1= 5.460
1-1	22.57	1.049	2E 2.0	13.00	16.13		Q=K*SQR(P):P= 16.13
		C=120		4.00	0.00		K= 5.620 V = 8.38
	22.57	0.1627		17.00	2.77		
1-2	22.52	1.049		13.00	18.90	18.90	K= 5.460 P= 17.01
		C=120		0.00	0.00	1.89	VELOCITY = 16.73
	45.09	0.5854		13.00	7.61	17.01	
1-3	25.53	1.049		12.50	26.51	26.51	K= 5.460 P= 21.87
		C=120		0.00	0.00	4.64	VELOCITY = 26.20
	70.62	1.3427		12.50	16.78	21.87	
1-4	34.74	1.452	OE 4.0	27.50	43.29	43.29	K= 5.460 P= 40.48
		C=120	1T 8.0	8.00	0.00	2.81	VELOCITY = 20.40
	105.36	0.5778		35.50	20.51	40.48	
1	105.36				63.80		K 2= 13.190
2-1	22.57	1.049	1E 2.0	15.00	16.13		Q=K*SQR(P):P= 16.13
		C=120		2.00	0.00		K= 5.620 V = 8.38
	22.57	0.1627		17.00	2.77		
2-2	22.52	1.049		14.00	18.90	18.90	K= 5.460 P= 17.01
		C=120		0.00	0.00	1.89	VELOCITY = 16.73
	45.09	0.5854		14.00	8.20	17.01	
2-3	25.85	1.049		12.00	27.10	27.10	K= 5.460 P= 22.42
		C=120		0.00	0.00	4.68	VELOCITY = 26.32
	70.94	1.3540		12.00	16.25	22.42	
2-4	34.76	1.452	OE 4.0	27.00	43.35	43.35	K= 5.460 P= 40.52
		C=120	1T 8.0	8.00	0.00	2.83	VELOCITY = 20.47
	105.70	0.5813		35.00	20.35	40.52	
2	105.70				63.70		K 3= 13.240
ARM	22.50	1.049	1E 2.0	3.00	16.03		Q=K*SQR(P):P= 16.03
		C=120	1T 5.0	7.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		10.00	1.62		

***** SPRINKLER SYSTEMS INC. *****							
JOB- 511 CONGRESS ST. 8TH FLOOR			JOB NO 95044		DATE 10/04/95 PAGE 3		
*****AREA 1-- .10/1500+100*****							
=====							
HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
=====							
3-2	22.50				17.65		K 4= 5.360

3-1	22.57	1.049 C=120	2E 2.0	17.00 4.00	16.13 0.00		Q=K*SQR(P):P= 16.13 K= 5.620 V = 8.38
	22.57	0.1627		21.00	3.42		

3-2	22.52	1.049 C=120		13.00 0.00	19.55 0.00	19.55	K= 5.360 P= 17.66 VELOCITY = 16.73
	45.09	0.5854		13.00	7.61	17.66	

3-3	25.44	1.049 C=120		14.00 0.00	27.16 0.00	27.16	K= 5.360 P= 22.53 VELOCITY = 26.17
	70.53	1.3395		14.00	18.75	22.53	

3-4	35.82	1.452 C=120	0E 4.0 1T 8.0	26.50 8.00	45.91 0.00	45.91	K= 5.460 P= 43.04 VELOCITY = 20.59
	106.35	0.5879		34.50	20.28	43.04	

3	106.35				66.19		K 5= 13.070

1	108.38	2.635 C=120		10.50 0.00	67.52 0.00		Q=K*SQR(P):P= 67.52 K= 13.190 V = 6.37
	108.38	0.0334		10.50	0.35		

2	108.19	2.635 C=120		6.50 0.00	67.87 0.00	67.87	K= 13.240 P= 66.77 VELOCITY = 12.73
	216.57	0.1203		6.50	0.78	66.77	

3	106.35	2.635 C=120		12.00 0.00	68.65 0.00	68.65	K= 13.070 P= 66.21 VELOCITY = 18.99
	322.92	0.2519		12.00	3.02	66.21	

10	322.92				71.67		K 6= 38.140

10	322.92	2.635 C=120	2E 6.0	10.00 12.00	71.67 0.00		QA= 322.9 PT= 71.67 VELOCITY = 18.99
	322.92	0.2519		22.00	5.54		

11	0.00	3.068 C=120	2E 7.0 4T15.0	35.00 74.00	77.21 0.00		QA= 0.0 PT= 77.21 VELOCITY = 14.00
	322.92	0.1200		109.00	13.09		

12	0.00	4.026 C=120	0E10.0 1T20.0	5.00 24.00	90.30 0.00		QA= 0.0 PT= 90.30 VELOCITY = 8.13
	322.92	0.0319	4.00F.	29.00	0.93		
=====							

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT FE PF	PT PV PN	***** NOTES *****
B	322.92				91.23		K 7= 33.810
B	322.92	6.065 C=120		12.00 0.00	91.23 0.00		QA= 322.9 PT= 91.23 VELOCITY = 3.58
	322.92	0.0043		12.00	0.05		
C	0.00	6.065 C=120		12.00 0.00	91.23 0.00		QA= 0.0 PT= 91.23 VELOCITY = 3.58
	322.92	0.0043		12.00	0.05		
D	0.00	6.065 C=120		12.00 0.00	91.33 0.00		QA= 0.0 PT= 91.33 VELOCITY = 3.58
	322.92	0.0043		12.00	0.05		
E	0.00	6.065 C=120		12.00 0.00	91.33 0.00		QA= 0.0 PT= 91.33 VELOCITY = 3.58
	322.92	0.0043		12.00	0.05		
F	0.00	6.065 C=120		12.00 0.00	91.43 0.00		QA= 0.0 PT= 91.43 VELOCITY = 3.58
	322.92	0.0043		12.00	0.05		
G	0.00	6.065 C=120	4E14.0	24.00 56.00	91.48 0.00		QA= 0.0 PT= 91.48 VELOCITY = 3.58
	322.92	0.0043		80.00	0.35		
H	0.00	6.065 C=120	4E14.0 1T30.0	26.00 86.00	91.83 0.00		QA= 0.0 PT= 91.83 VELOCITY = 3.58
	322.92	0.0043		112.00	0.49		
I	0.00	6.065 C=120	2E14.0	29.00 28.00	92.32 0.00		QA= 0.0 PT= 92.32 VELOCITY = 3.58
	322.92	0.0043		57.00	0.25		
J	0.00	6.065 C=120	1E14.0 1T30.0	17.00 44.00	92.57 0.00		QA= 0.0 PT= 92.57 VELOCITY = 3.58
	322.92	0.0043		61.00	0.27		
K	0.00	6.065 C=120	1E14.0	5.00 49.00	92.84 0.00		QA= 0.0 PT= 92.84 VELOCITY = 3.58
	322.92	0.0043	35.00F.	54.00	0.23		
100	0.00	3.065 C=120		0.75 0.00	93.07 0.00		QA= 0.0 PT= 93.07 VELOCITY = 14.03
	322.92	0.1206		0.75	0.09		
PUMP	100.00	6.065 C=120		0.00 0.00	93.16 49.81		QA= 100.0 PT= 93.16 VELOCITY = 4.69
	422.92	0.0071		0.00	0.00		FE= FOR HT. OF 115.0

***** SPRINKLER SYSTEMS INC. *****
 JOB- 511 CONGRESS ST. 8TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 5
 ***** AREA 1-- .10/1500+100 *****

HYDRLC.	QA	DIA.	EQUIV.	PIPE	PT	PT	
REF.	FLOW	"C"	FITTING	FTGS.	PE	FV	***** NOTES *****
POINT	QT	LOSS/F	LENGTHS	TOT.	PF	PN	
	422.92				142.97		K 8= 35.370
HOSE							

***** SPRINKLER SYSTEMS INC. *****							
JOB- 511 CONGRESS ST. 8TH FLOOR		JOB NO 95044		DATE 10/04/95 PAGE 6			
*****AREA 2--.10/1500+100*****							
=====							
HYDRLC. REF. POINT	QA FLOW QT	"C" DIA. LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
=====							
TYP	22.50	1.049	OE 2.0	1.00	16.03		Q=K*SQR(P):P= 16.03
		C=120	1T 5.0	5.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		6.00	0.97		

DROP	22.50				17.00		K 9= 5.460

4-1	23.21	1.049	1E 2.0	9.00	17.05		Q=K*SQR(P):P= 17.05
		C=120		2.00	0.00		K= 5.620 V = 8.61
	23.21	0.1713		11.00	1.89		

4-2	22.51	1.049		6.00	18.94	18.94	K= 5.460 P= 17.00
		C=120		0.00	0.00	1.94	VELOCITY = 16.96
	45.72	0.6007		6.00	3.60	17.00	

4-3	23.24	1.049	OE 2.0	2.50	22.54	22.54	K= 5.460 P= 18.12
		C=120	1T 5.0	5.00	0.00	4.42	VELOCITY = 25.58
	68.96	1.2849		7.50	9.64	18.12	

4	68.96				32.18		K 10= 12.160

4-4	22.50	1.049	1E 2.0	4.50	16.03		Q=K*SQR(P):P= 16.03
		C=120	1T 5.0	7.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		11.50	1.86		

4	22.50				17.89		K 11= 5.320

ARM	22.50	1.049	1E 2.0	2.50	16.03		Q=K*SQR(P):P= 16.03
		C=120	1T 5.0	7.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		9.50	1.54		

5-3	22.50				17.57		K 12= 5.370

5-1	22.99	1.049	1E 2.0	11.00	16.74		Q=K*SQR(P):P= 16.74
		C=120		2.00	0.00		K= 5.620 V = 8.53
	22.99	0.1683		13.00	2.19		

5-2	22.51	1.049		6.00	18.93	18.93	K= 5.460 P= 17.00
		C=120		0.00	0.00	1.93	VELOCITY = 16.88
	45.50	0.5953		6.00	3.57	17.00	

5-3	22.88	1.049	OE 2.0	3.00	22.50	22.50	K= 5.370 P= 18.15
		C=120	1T 5.0	5.00	0.00	4.35	VELOCITY = 25.37
	68.38	1.2650		8.00	10.12	18.15	
=====							

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
5	68.38				32.62		K 13= 11.970
ARM	22.50	1.049 C=120	1E 2.0 2T 5.0	5.00 12.00 17.00	16.03 0.00 2.75		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
6-3	22.50	0.1618			18.78		K 14= 5.190
6-1	23.35	1.049 C=120	1E 2.0	11.00 2.00 13.00	17.26 0.00 2.25		Q=K*SQR(P):P= 17.26 K= 5.620 V = 8.66
6-2	22.85	1.049 C=120		6.00 0.00 6.00	19.51 0.00 3.67	19.51 1.99 17.52	K= 5.460 P= 17.52 VELOCITY = 17.14
6-3	22.50	1.049 C=120	0E 2.0 1T 5.0	3.00 5.00 8.00	23.18 0.00 10.21	23.18 4.39 18.79	K= 5.190 P= 18.79 VELOCITY = 25.49
6	68.70	1.2759			33.39		K 15= 11.890
ARM	22.50	1.049 C=120	1E 2.0 1T 5.0	3.00 7.00 10.00	16.03 0.00 1.62		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35
7-2	22.50	0.1618			17.65		K 16= 5.360
7-1	22.98	1.049 C=120	1E 2.0	15.00 2.00 17.00	16.72 0.00 2.86		Q=K*SQR(P):P= 16.72 K= 5.620 V = 8.53
7-2	22.52	1.049 C=120	0E 2.0 1T 5.0	3.00 5.00 8.00	19.58 0.00 4.76	19.58 1.93 17.65	K= 5.360 P= 17.65 VELOCITY = 16.88
7	45.50	0.5953			24.34		K 17= 9.220
8-1	22.50	1.049 C=120	2E 2.0	17.50 4.00 21.50	16.03 0.00 3.48		Q=K*SQR(P):P= 16.03 K= 5.620 V = 8.35

***** SPRINKLER SYSTEMS INC. *****							
JOB- 511 CONGRESS ST. 8TH FLOOR				JOB NO 95044		DATE 10/04/95 PAGE 8	
*****AREA 2--.10/1500+100*****							
=====							
HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
=====							
8-2	22.90	1.049	1E 2.0	5.50	19.51	19.51	K= 5.460 P= 17.59
		C=120	1T 5.0	7.00	0.00	1.92	VELOCITY = 16.84
	45.40	0.5929		12.50	7.41	17.59	

8	45.40				26.92		K 18= 8.750

ARM	22.50	1.049	1E 2.0	3.00	16.03		Q=K*SQR(P) :P= 16.03
		C=120	1T 5.0	7.00	0.00		K= 5.620 V = 8.35
	22.50	0.1618		10.00	1.62		

9-1	22.50				17.65		K 19= 5.360

4	101.16	2.635		10.50	33.49		Q=K*SQR(P) :P= 33.49
		C=120		0.00	0.00		K= 17.480 V = 5.95
	101.16	0.0294		10.50	0.31		

5	68.89	2.635		12.00	33.80	33.80	K= 11.970 P= 33.12
		C=120		0.00	0.00	0.68	VELOCITY = 10.00
	170.05	0.0769		12.00	0.92	33.12	

6	68.71	2.635		8.00	34.72	34.72	K= 11.890 P= 33.35
		C=120		0.00	0.00	1.33	VELOCITY = 14.04
	238.76	0.1441		8.00	1.15	33.39	

7	53.66	2.635		5.00	35.87	35.87	K= 9.220 P= 33.87
		C=120		0.00	0.00	2.00	VELOCITY = 17.19
	292.42	0.2096		5.00	1.05	33.87	

8	51.14	2.635	1E 6.0	10.00	36.92	36.92	K= 8.750 P= 34.16
		C=120		6.00	0.00	2.76	VELOCITY = 20.20
	343.56	0.2825		16.00	4.52	34.16	

9-1	33.10	2.635	0E 6.0	45.50	41.44	41.44	K= 5.360 P= 38.13
		C=120	1T12.0	24.00	0.00	3.31	VELOCITY = 22.15
	376.66	0.3349	12.00F.	69.50	23.28	38.13	

10	376.66				64.72		K 20= 46.820


10	376.66	2.635	2E 6.0	10.00	64.72		QA= 376.6 PT= 64.72
		C=120		12.00	0.00		VELOCITY = 22.15
	376.66	0.3349		22.00	7.37		

11	0.00	3.068	2E 7.0	35.00	72.09		QA= 0.0 PT= 72.09
		C=120	4T15.0	74.00	0.00		VELOCITY = 16.33
	376.66	0.1596		109.00	17.40		
=====							

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT PV PN	***** NOTES *****
12	0.00 376.66	4.026 C=120 0.0425	0E10.0 1T20.0 4.00F.	5.00 24.00 29.00	89.49 0.00 1.23		QA= 0.0 PT= 89.49 VELOCITY = 9.48
B	376.66				90.72		K 21= 39.550
B	376.66 376.66	6.065 C=120 0.0057		12.00 0.00 12.00	90.72 0.00 0.07		QA= 376.6 PT= 90.72 VELOCITY = 4.18
C	0.00 376.66	6.065 C=120 0.0057		12.00 0.00 12.00	90.79 0.00 0.07		QA= 0.0 PT= 90.79 VELOCITY = 4.18
D	0.00 376.66	6.065 C=120 0.0057		12.00 0.00 12.00	90.86 0.00 0.07		QA= 0.0 PT= 90.86 VELOCITY = 4.18
E	0.00 376.66	6.065 C=120 0.0057		12.00 0.00 12.00	90.93 0.00 0.07		QA= 0.0 PT= 90.93 VELOCITY = 4.18
F	0.00 376.66	6.065 C=120 0.0057		12.00 0.00 12.00	91.00 0.00 0.07		QA= 0.0 PT= 91.00 VELOCITY = 4.18
G	0.00 376.66	6.065 C=120 0.0057	4E14.0	24.00 56.00 80.00	91.07 0.00 0.46		QA= 0.0 PT= 91.07 VELOCITY = 4.18
H	0.00 376.66	6.065 C=120 0.0057	4E14.0 1T30.0	26.00 86.00 112.00	91.53 0.00 0.65		QA= 0.0 PT= 91.53 VELOCITY = 4.18
I	0.00 376.66	6.065 C=120 0.0057	2E14.0	29.00 28.00 57.00	92.18 0.00 0.33		QA= 0.0 PT= 92.18 VELOCITY = 4.18
J	0.00 376.66	6.065 C=120 0.0057	1E14.0 1T30.0	17.00 44.00 61.00	92.51 0.00 0.35		QA= 0.0 PT= 92.51 VELOCITY = 4.18
K	0.00 376.66	6.065 C=120 0.0057	1E14.0 35.00F.	5.00 49.00 54.00	92.86 0.00 0.31		QA= 0.0 PT= 92.86 VELOCITY = 4.18
100	0.00 376.66	3.065 C=120 0.1604		0.75 0.00 0.75	93.17 0.00 0.12		QA= 0.0 PT= 93.17 VELOCITY = 16.37

***** SPRINKLER SYSTEMS INC. *****
 JOB- 511 CONGRESS ST. 8TH FLOOR JOB NO 95044 DATE 10/04/95 PAGE 10
 ***** AREA 2-- .10/1500+100*****

HYDRLC. REF. POINT	QA FLOW QT	DIA. "C" LOSS/F	EQUIV. FITTING LENGTHS	PIPE FTGS. TOT.	PT PE PF	PT FV PN	***** NOTES *****
	100.00	6.065		0.00	93.29		QA= 100.0 PT= 93.29
PUMP		C=120		0.00	49.81		VELOCITY = 5.29
	476.66	0.0089		0.00	0.00		PE= FOR HT. OF 115.0
	476.66				143.10		K 22= 39.850
HOSE							




...FIRE PROTECTION BY COMPUTER DESIGN

 ** SPRINKLER SYSTEMS INC. **
 ** LEWISTON, ME 04240 **
 ** 207-782-0104 **

```
*****
* CONTRACTOR          SPRINKLER SYSTEMS INC.
* NAME                511 CONGRESS ST.  STANDPIPE
* LOCATION            511 CONGRESS STREET,  PORTLAND,  MAINE
* SYSTEM NO.          EX.STPIPE
* CONTRACT NO.        95044
*****
```

WATER SUPPLY GRAPH NO. N 1.85


Factory
Mutual
System



DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME
5 1995

WATER SUPPLY GRAPH NO. N 1.85

Factory
Mutual
System



DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME
5 1995

Factory Mutual System

