Patrick Scally
738 Fort Hill Road
Gorham, ME 04038
(207) 710-9100
pizzapatrick@yahoo.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/22/15

NFPA and IBC Classification M for proposed use of existing structure located at 
Avenue, Portland, ME.

First floor space approximately 1100 sq. ft.

Fire extinguisher(s) per code

Furthest travel point to building exit is currently 64 feet; if a rear door is required, the furthest travel point to the building exist would be 32 feet and would include an emergency exit sign at doorway

Location of fire extinguisher TBD with confirmation if a rear door is required. Please advise.