Approved for Historic Preservation
Certificate of Appropriateness
Date: 01/12/16

Dear Tom,

As we discussed today, I am prepared to sign off on your application for a projecting dire
Mechanics Hall once we receive the sign permit application. Approval will be subject to tl
the position of the sign be revised as shown in the attached marked-up photo.

Regarding the cabinet sign, I have reservations about the proposed placement of the cabinet, as it will impact the recessed panel beside the entryway, which is a significant architectural feature. You have indicated that you will explore the possibility of installing a cabinet on the side wall of the granite pier flanking the entrance, which will likely require a cabinet of revised proportions. It will be important to provide at least an inch of space on either side of the cabinet, so that it does not appear forced into the space. Regarding the cabinet frame's finish, I believe the black finish would be preferable, as it would provide a more formal appearance in keeping with this formal institutional building.

I understand that you will be completing the sign permit application. Once I receive the application, I am prepared to sign off on it with the above conditions.

Deb