

(COPY)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 Congress St.

Date of Issue 10-11-71

Issued to Lum's

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 71/995, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Restaurant

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings


Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

9/21/71

Bois,

Wetland has improved
then location on
right - says O.K.

C.B.



RECEIVED
SEP 23 1971
DEPT OF BLDG INSP
CITY OF PORTLAND

Note: I believe I already gave you the dia of existing floor
if you don't remember call me, and I'll double check
- I think it was 15 1/4" C.D.



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine, Sept. 20, 1971

PERMIT ISSUED

SEP 22 1971

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, install, the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications if any, submitted herewith and the following specifications:

Location 601 Congress St. Within Fire Limits? _____ Dist. No. _____
 Owner's name and address ROSSI, Maurice Dreese, 999 Congress St. Telephone _____
 Lessee's name and address Lum's, 601 Congress St. Telephone _____
 Contractor's name and address Norman Boulay, 373 Pond Rd., Lewiston Telephone _____
 Architect _____ Specifications _____ Plans yes No. of sheets 1
 Proposed use of building Restaurant No. families _____
 Last use _____ No. families _____
 Material _____ No. stories _____ Heat _____ Style of roof _____ Flooring _____
 Other buildings on same lot _____
 Estimated cost \$ _____ Fee \$ 10.

General Description of New Work

To install ventilation system for cooking equipment as per plans

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Contractor 601 Congress

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing Lumber—kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____ 2nd _____ 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____ 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

OK 9-21-71 AD

Miscellaneous

Will work require disturbing of any tree on a public street? _____
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

CS 301

INSPECTION COPY

Signature of owner

By:

Lum's (Rossi Sheet Metal)
Salvatore Masiello
 Salvatore Masiello

Permit No. 11/1147
Location 601 Longview St.
Owner Therese Moore
Date of permit 4/22/71
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn _____
Cert. of Occupancy issued 4/22/71
~~Subg. Out Notice~~ CART
Form Check Notice _____

NOTES

[Handwritten mark: a large 'X' with a horizontal line through it, spanning the first few lines of the notes section.]

CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. 55365
 Issued 10-4
 Portland, Maine Oct 4, 1971

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address *Luna's 601 Congress St.* Tel. *774-3129*
 Contractor's Name and Address *Morris Electric Co. 65 High Ave.*

Location Use of Building Number of Stories
 Number of Families Apartments Stores Alterations
 Description of Wiring: New Work Additions

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
 No. Light Outlets Plugs Light Circuits Plug Circuits
 FIXTURES: No. Fluor. or Strip Lighting (No. feet)
 SERVICE: Pipe Cable Underground No. of Wires Size
 METERS: Relocated Added Total No. Meters
 MOTORS: Number Phase H. P. Amps Volts Starter
 HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
 Commercial (Oil) No. Motors Phase H.P.
 Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
 Elec. Heaters Watts
 Miscellaneous *Signs* Watts Extra Cabinets or Panels
 Transformers Air Conditioners (No. Units) Signs (No. Units)
 Will commence 10/4 1971 Ready to cover in 19 Inspection 10/4 1971
 Amount of Fee \$ 2.00 Signed *J. Morris*

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1	2	3
7	8	9
		10
		11
		12

REMARKS:

INSPECTED BY *J. W. Hebert* (OVER)

LOCATION *Conny ST 601*
 INSPECTION DATE *10/31/71*
 WORK COMPLETED *10/31/71*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	
1 to 30 Outlets	
31 to 60 Outlets	
Over 60 Outlets, each Outlet	(including switches)
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	(including switches)
SERVICES	
Single Phase	
Three Phase	
MOTORS	
Not exceeding 50 H.P.	
Over 50 H.P.	
HEATING UNITS	
Domestic (Oil)	
Commercial (Oil)	
Electric Heat (Each Room)	
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers, etc. — Each Unit	
TEMPORARY WORK (Limited to 6 mon. from date of permit)	
Service, Single Phase	
Service, Three Phase	
Wiring, 1-50 Outlets	
Wiring, each additional outlet over 50	
Circuses, Carnivals, Fairs, etc.	
MISCELLANEOUS	
Distribution Cabinet or Panel, per unit	
Air Conditioners, per unit	
Signs, per unit	
ADDITIONS	
5 Outlets, per unit	

\$ 2.00
 3.00
 .05
 2.00
 4.00
 .75
 1.50
 1.00
 2.00
 1.00
 .02
 10.00
 1.00
 2.00
 2.00



APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 4, 1971

PERMIT ISSUED

OCT 5 1971
239

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 601 Congress Street

Use of Building Restaurant

No. Stories 1

Neighb. Building Existing "

Name and address of owner of appliance

Dum's Restaurant, 601 Congress St.

Telephone

Installer's name and address

General Description of Work

To install 1-electric fry grille; 2-electric friolators
Wells - Model Bnd
Power Char broiler

IF HEATER, OR POWER BOILER

Any burnable material in floor surface or beneath?

Kind of fuel?

Location of appliance

If so, how protected?

Minimum distance to burnable material, from top of appliance or casing top of furnace

From front of appliance

From side or back of appliance

From top of smoke pipe

Size of chimney flue

If gas fired, how vented?

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Labelled by underwriters' laboratories?

Does oil supply line feed from top or bottom of tank?

Size of vent pipe

Number and capacity of tanks

No.

Name and type of burner

Will operator be always in attendance?

Type of floor beneath burner

Location of oil storage

Low water shut off

Will all tanks be more than five feet from any flame?

Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Any burnable material in floor surface or beneath? no

Height of legs, if any 4"

Location of appliance

If so, how protected?

Skirting at bottom of appliance?

From front of appliance 4"

Size of chimney flue

Is hood to be provided? yes

If gas fired, how vented?

Distance to combustible material from top of appliance?
From sides and back enclosed by stainless steel with shield

Other connections to same flue

If so, how vented? thru roof Forced or gravity?

Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 8.00 ~~50.00 for one heater, etc. \$1.00 additional for each additional heater, etc. in same building at same time~~

APPROVED:

OCT 10 5 71 - JAE

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Dum's Restaurant

John M. Murphy

Signature of Installer By:

CS 300

INSPECTION COPY

Permit No. 11/1239
Location 1611 Congress St.
Owner James H. H. H. H. H.
Date of permit 11/5/11
Notif. closing-in
Insyn. closing-in
11/5/11
Final Insyn.
Cert. of Occupancy issued

NOTES

Handwritten notes and signatures on lined paper.



APPLICATION FOR PERMIT TO ERECT
SIGN OVER PUBLIC SIDEWALK OR STREET

PERMIT ISSUED

SEP 22 1971

1948

CITY OF PORTLAND

Portland, Maine, Sept. 21, 1971

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 601 Congress St. Within Fire Limits? Dist. No.

Owner of building to which sign is to be attached Lum's, 601 Congress St.

Name and address of owner of sign Lum's Restaurant, " "

Contractor's name and address Coyne Sign Co, 66 Cove St. Telephone

When does contractor's bond expire? Dec. 31, 1971

Information Concerning Building

No. stories 1 Material of wall to which sign is to be attached masonry

Details of Sign and Connections

Building owner's consent and agreement filed with application

Electric? yes Vertical dimension after erection 4'6" Horizontal 15'

Weight 75# each letter, Will there be any hollow spaces? yes Any rigid frame? no

Material of frame No. advertising faces one material plastic

No. rigid connections four ea. letter Are they fastened directly to frame of sign? yes

No. through bolts 16 Size 1/2 inch Location, top or bottom top & bottom

No. guys none material Size

Minimum clear height above sidewalk or street 10 ft. plus

Maximum projection into street 15 inches Fee \$ 11.75

Signature of contractor

INSPECTION COPY

Permit No. 71/1148

Location 601 Congress St

Owner Lima Restaurant

Date of permit 9/22/71


Sign Contractor

Final Inspn.

NOT

9/22/71

CR
78



545-601 CONVERSE STREET #2

2



THE FOLLOWING INFORMATION WAS OBTAINED FROM THE RECORDS OF THE
BUREAU OF THE DISTRICT ATTORNEY, NEW YORK CITY, ON JANUARY 1, 1964.
RECORD OF THE DISTRICT ATTORNEY, NEW YORK CITY, ON JANUARY 1, 1964.
RECORD OF THE DISTRICT ATTORNEY, NEW YORK CITY, ON JANUARY 1, 1964.
RECORD OF THE DISTRICT ATTORNEY, NEW YORK CITY, ON JANUARY 1, 1964.
RECORD OF THE DISTRICT ATTORNEY, NEW YORK CITY, ON JANUARY 1, 1964.



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date March 17, 19 82
Receipt and Permit number A 88182

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Intersection of High & Congress Streets

OWNER'S NAME: City of Portland, Me. ADDRESS: 389 Congress Street

		FEES
OUTLETS:		
Receptacles	Switches	Plugmold
ft. TOTAL <u>1-30</u>		<u>3.00</u>
FIXTURES: (number of)		
Incandescent <u>X</u>	Flourescent	(not strip) TOTAL <u>32</u>
		<u>5.20</u>
Strip Flourescent	ft.	
SERVICES:		
Overhead	Underground <u>X</u>	Temporary
TOTAL amperes <u>100</u>		<u>3.00</u>
METERS: (number of) <u>2</u>		<u>1.00</u>
MOTORS: (number of)		
Fractional		
1 HP or over		
RESIDENTIAL HEATING:		
Oil or Gas (number of units)		
Electric (number of rooms)		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler)		
Oil or Gas (by separate units)		
Electric Under 20 kws	Over 20 kws	
APPLIANCES: (number of)		
Ranges	Water Heaters	
Cook Tops	Disposals	
Wall Ovens	Dishwashers	
Dryers	Com.actors	
Fans	O'rers (denote)	
TOTAL		
MISCELLANEOUS: (number of)		
Branch Panels		
Transformers		
Air Conditioners Central Unit		
Separate Units (windows)		
Signs 20 sq. ft. and under		
Over 20 sq. ft.		
Swimming Pools Above Ground		
In Ground		
Fire/Burglar Alarms Residential		
Commercial		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under		
over 30 amps		
Circus, Fairs, etc.		
Alterations to wires		
Repairs after fire		
Emergency Lights, battery		
Emergency Generators		

INSTALLATION FEE DUE: _____
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)
TOTAL AMOUNT DUE: 12.20

INSPECTION:

Will be ready on _____, 19__; or Will Call X

CONTRACTOR'S NAME: A D Electric Inc.

ADDRESS: 64 Grove St. Lewiston, Me.

TEL.: 375-6616

MASTER LICENSE NO.: 2801 SIGNATURE OF CONTRACTOR: _____

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS —

Permit Number 88182
Location 601 Congress St.
Owner City
Date of Permit 3-17-82
Final Inspection 10-20-82
By Inspector Calley
Permit Application Register Page No. 112

INSPECTIONS: Service ✓ by Calley
Service called in 7-28-82
Closing-in 7-28-82 by Calley

PROGRESS INSPECTIONS:
10-20-82 ✓
✓
✓
✓
✓
✓
✓

CODE
COMPLIANCE
COMPLETED
10-20-82

DATE: _____

REMARKS:

Inspections made when in vicinity and
not recorded.



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

01064

ZONING LOCATION

PORTLAND, MAINE, Oct. 7, 1981

PERMIT ISSUED

OCT. 7 1981

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 601 Congress Street 37-E-1 Fire District #1 ☐ #2 ☐
1. Owner's name and address City of Portland, Maine Telephone
2. Lessee's name and address Telephone
3. Contractor's name and address The IIIrd Wrecking Corp. - 40 Commercial St. Telephone 774-0900
4. Architect Specifications Plans No. of sheets
Proposed use of building No. families
Last use restaurant No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ Fee \$ 25.00

FIELD INSPECTOR—Mr.

GENERAL DESCRIPTION

This application is for:

@ 775-5451

Dwelling

Ext. 234

Garage

Masonry Bldg.

Metal Bldg.

Alterations

Demolitions

Change of Use

Other

To demolish 1 story restaurant
utilities called from office.

Stamp of Special Conditions

Sent to Health Dept. 10-7-81

Rec'd from Health Dept. 10-7-81

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 ☐ 2 ☐ 3 ☒ 4 ☐

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot . . . , to be accommodated . . . number commercial cars to be accommodated . . .
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER

Will work require disturbing of any tree on a public street?

ZONING:

BUILDING CODE:

Will there be in charge of the above work a person competent

Fire Dept.:

to see that the State and City requirements pertaining thereto

Health Dept.:

are observed?

Others:

Signature of Applicant: Paul V. McGuire Phone # same

Type Name of above The IIIrd Wrecking Corp. 1 ☐ 2 ☐ 3 ☒ 4 ☐

Paul V. McGuire

Other

and Address

FIELD INSPECTOR'S COPY

4

NOTES

Completed without final exp.

Permit No. 81/1964

Location 641 Longshore St.

Owner City of Oakland

Date of permit 10-7-81

Approved 10-7-81

CITY OF PORTLAND, MAINE
BUILDING & INSPECTION SERVICES

Date Oct. 7, 1981

To: The III Wrecking Corporation
(contractor)

40 Commerical Street

With relation to permit applied for to demolish a 1 story restaurant

at (address) 601 CONGRESS ST. belonging to


(owner) CITY OF PORTLAND, MAINE. It is unlawful to
commence demolition work until a permit has been issued from this
department.

Section 6 of the Ordinance for rodent and vermin control provides,
"It shall be unlawful to demolish a building or structure unless
provision is made for rodent and vermin eradication. No permit
for the demolition of a building or structure shall be issued by
the Building and Inspection Services Department until and unless
provisions for rodent and vermin eradication have been carried out
under supervision of a pest control operator registered with the
Health Department."

The building permit for demolition cannot be issued until the
provisions of this section have been satisfied. It is the obli-
gation of owner or demolition contractor or both to take up with
the Health Department the matter of complying with this section,
being prepared to inform that department what registered pest
control operator is to be employed.

NOTICE -- PER MUNICIPAL CODE
A PERMIT TO DEMOLISH OR REMOVE A
STRUCTURE SHALL EXPIRE THIRTY
(30) DAYS AFTER THE DATE OF
ISSUANCE.

Very truly yours,


Walter W. Hilton
chief Building Inspector

Health Department comments: No rodent or vermin evidence

Copies to:

- 2 - Health - Environ. (Mr. Vandoloski)
- 1 - Health - (Mr. Noyes)
- 1 - Public Works (Phil Mullin)
- 1 - Fire Dept.

BUILDING INSPECTIONS
CITY OF PORTLAND, MAINE
DEPARTMENT OF URBAN DEVELOPMENT
DEMOLITION APPLICATION

Permission to _____ hereby requests
_____ planning on the following date: _____

_____ contractors are hereby required to notify and meet the following
_____ departments on the site of proposed demolition.

CITY APPROVAL:

Central Maine Power Co. _____ Date 10/7/81
Phone Dept. 772-7411 *in the Dept* R. Hamilton
New England Telephone Co. _____ Date 10/7/81
Mr. Jones 797-1195/797-1943 Rick Gillison
797-1125
Northern Utilities, Inc. _____ Date 10/7/81
Mr. Corry 797-8000 ext. 47 Mr. Don Cote
2 Sand - for Dept.
Portland Water District _____ Date 10/7/81 By Friday
Dispatcher 774-5961 ext 31 James Pandiscio *Mr. Morse*
Slac Cable TV _____ Date 10/7/81
Mr. Smith/Mr DesRochers M. DesRochers
1-3431 _____ Date 10/7/81 By Friday

OF PORTLAND:

_____ Date _____
Fire Division
7-5302/775-5451 ext. 470 _____ Date _____
Walk Division
Slac Wks. ext. 488/489 _____ Date _____
Slac Division
7-5451 ext. 463/469 _____ Date _____
Alarm
Allen 775-6351 ext. 321 _____ Date _____
Entry
Jones 775-2921 ext. 33 _____ Date _____

_____ I have contacted ALL the above Utility companies and/or City Departments
_____ locations of Utilities and they have signed this sheet.

Signature: Paul W. McSwiney

IN EMERGENCY, THE DATE OF THE EMERGENCY: _____

Date 10/7/81

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

NOVEMBER 07, 1996

RICE GEOFFREY I
655 CONGRESS ST
PORTLAND ME 04101

Re: 600 CONGRESS ST
CBL: 039- - A-013-001-01
DU: 7

Dear Mr. Rice:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

A handwritten signature in dark ink, appearing to read "Arthur Rowe".

Arthur Rowe
Code Enforcement Officer

A handwritten signature in dark ink, appearing to read "Tammy Munson".

Tammy Munson
Code Enfc.Offc./ Field Supv.