

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
181 HIGH STREET LLC

Located at
173 HIGH ST

PERMIT ID: 2015-01615 **ISSUE DATE:** 09/08/2015 **CBL:** 037 E006009

has permission to **Demolition of existing masonry façade on High Street and replacement with a steel tube bumper for vehicle impact and cable rail with fencing as pedestrian guard rail.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
Parking Garage

Building Inspections
Use Group: S-2 **Type:** 1B
Low hazard storage - Parking Garage
ENTIRE
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01615	Date Applied For: 07/07/2015	CBL: 037 E006009
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Parking garage		Proposed Project Description: Demolition of existing masonry façade on High Street and replacement with a steel tube bumper for vehicle impact and cable rail with fencing as pedestrian guard rail.		
Dept: Zoning	Status: Approved	Reviewer: Ann Machado	Approval Date: 08/31/2015	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/04/2015	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) In lieu of a Statement of Special Inspections, there will be periodic oversight by Becker Structural Engineers (BSE). All copies of written field reports and a written summary of the project will be provided to The City of Portland upon completion.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 07/10/2015	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 09/03/2015	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
2) All construction shall comply with City Code Chapter 10.				