Eastland Hotel

Portland, ME

PROJECT:

DRAWING:

RISERS

REVISIONS

DATE: 10/02/12

SCALE: NTS

DRAWN BY: RJH

APPROVED BY: –

SHEET: 5

CONSULTANT:

FIRE - SECURITY - ACCESS - CCTV

525 US ROUTE ONE
FALMOUTH, ME 04105

Phone: (207) 775-5750
Fax: (207) 781-2084

5TH FLOOR

FRONT

ON EVAX 4
VOICE EVACUATION
PORT 2
HALL BY STAIR B
A 516 A 514 A 512 A 510 HALL BY 510 A 508 A 506 A 504 A 502 A 501 BY STAIR A A 503 BY 505 11.75 WATTS RETURN
AV SERVICE ELEVATOR AV ICE MACHINE AV TOWER ELEVATOR AV MAIN ELEVATOR

NOTE
1. ALL ROOM SPEAKERS ARE SET AT .5 WATT.
2. ALL STAIRWAY SPEAKER AND ICE MACHINE ROOMS ARE SET AT .25 WATT.
3. ALL OTHER SPEAKERS ARE SET AT 1 WATT UNLESS OTHERWISE NOTED.

SIDE

ON EVAX 4
VOICE EVACUATION
PORT 1
HALL BY 521 A 519 A 521 HALL BY 527 A 523 A 525 A 527 HALL BY 527 A 529 A 531 A 533 A 530 A 532 TOWER ELEVATOR AV SERVICE ELEVATOR AV MAIN ELEVATOR
A 518 A 520 A 522 A 524 A 526 A 528 11.75 WATTS RETURN

4TH FLOOR

FRONT

ON EVAX 3
VOICE EVACUATION
PORT 4
HALL BY 421 A 419 A 421 A 423 A 425 A 427 HALL BY 427 A 429 A 431 A 433 A 432 A 430 TOWER ELEVATOR AV
A 418 A 420 A 422 A 424 A 426 A 428 11.75 WATTS RETURN

NOTE
1. ALL ROOM SPEAKERS ARE SET AT .5 WATT.
2. ALL STAIRWAY SPEAKER AND ICE MACHINE ROOMS ARE SET AT .25 WATT.
3. ALL OTHER SPEAKERS ARE SET AT 1 WATT UNLESS OTHERWISE NOTED.

SIDE

ON EVAX 3
VOICE EVACUATION
PORT 5
HALL BY STAIR B A 417 AV HALL BY 321 A 416 A 414 A 412 A 410 A 408 HALL BY 410 A 406 A 404 A 402 A 401 BY STAIR A AV 403 BY 405 11.75 WATTS RETURN
AV SERVICE ELEVATOR AV ICE MACHINE AV TOWER ELEVATOR AV MAIN ELEVATOR

3RD FLOOR

FRONT

ON EVAX 3
VOICE EVACUATION
PORT 3
HALL BY STAIR B AV A 316 A 314 A 312 A 310 A 308 HALL BY 309 A 306 A 304 A 302 A 301 BY STAIR A AV 303 HALL BY 305 11.25 WATTS RETURN
AV MAIN ELEVATOR AV ICE MACHINE AV SERVICE ELEVATOR AV TOWER ELEVATOR

NOTE
1. ALL ROOM SPEAKERS ARE SET AT .5 WATT.
2. ALL STAIRWAY SPEAKER AND ICE MACHINE ROOMS ARE SET AT .25 WATT.
3. ALL OTHER SPEAKERS ARE SET AT 1 WATT UNLESS OTHERWISE NOTED.

SIDE

ON EVAX 3
VOICE EVACUATION
PORT 2
A 319 A 321 HALL BY 321 A 323 A 325 A 327 HALL BY 327 A 329 A 331 A 333 A 332 A 330 TOWER ELEVATOR AV
A 318 A 320 A 322 A 324 A 326 A 328 11.75 WATTS RETURN

STAIR C SIDE