CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager		Inspector	Inspection Date	
PORTLAND HOTEL ASSOCIATES LLC		Suzanne Hunt	6/9/2008	
Locatation	CBL	Status	Inspection Type	
157 HIGH ST	037 E007001		Complaint-Inspection	

	Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1)	Exterior Various locations					
	Violation: Notes: Sec. 14.221.1. External Effects. B. The level of sound within the B3 shall not exceed 55 decimals on the A scale between 9 p.m. and 7 a.m And sixty decimals between 7 a.m. and 9 p.m.					

Comments: Meter set at 60s LEG , (90 dec max) went to site at 3 p.m.. Meter set in at 69. I ran it twice, both

reading were 69. I pointed the microphone out while resting it on the window sill. There were 4 large

fan systems, only two of which appeared to be running.