

. . . Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 24 PREBLE ST.
Drawing : 2 OF 2
Location : 2ND FLOOR OFFICE
Remote Area : 2
Contract : 1-05637-SP-17
Data File : 2ND FLOOR CALC..WXF

HYDRAULIC CALCULATIONS
for

Project name: 24 PREBLE ST.
Location: 2ND FLOOR OFFICE
Drawing no: 2 OF 2
Date: 8/11/2017

Design

Remote area number: 2
Remote area location: 2ND FLOOR OFFICE
Occupancy classification: LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 984 - SqFt
Coverage per sprinkler: 120/144/210 - SqFt
Type of sprinklers calculated: RELIABLE F1FR56 200* K=5.6
No. of sprinklers calculated: 18
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 456.598 - GPM @ 65.428 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 7/6/16
Location: CUMBERLAND AVE. PORTLAND, ME.
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: 170 KITTY HAWK AVE / / AUBURN, ME 04210
Phone number: 207-784-1507
Name of designer: EWM
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.) REMOTE AREA REDUCED PER NFPA 13 (2016) SEC. 11.2.3.2.3.1


Water Supply Curve C

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 2
Date 8/11/2017

City Water Supply:
C1 - Static Pressure : 84
C2 - Residual Pressure: 78
C2 - Residual Flow : 1363

Demand:
D1 - Elevation : 11.949
D2 - System Flow : 356.598
D2 - System Pressure : 65.428
Hose (Demand) : 100
D3 - System Demand : 456.598
Safety Margin : 17.778



Fittings Used Summary

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 3
Date 8/11/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	84.0	78	1363.0	83.207	456.6	65.428

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
HEAD	0.0	5.6	7.0	14.82	
HEAD2	0.0	5.6	14.06	21.0	
200	131.09	5.6	17.75	23.59	
201	130.42	5.15	19.74	22.89	K=K @ LIN1
202	130.42	5.15	19.64	22.83	K=K @ LIN1
203	131.09		20.73		
205	130.42	5.15	8.27	14.82	K=K @ LIN1
206	130.42	5.15	9.18	15.61	K=K @ LIN1
207	131.09		9.01		
208	130.42	5.15	8.93	15.4	K=K @ LIN1
209	131.09		9.16		
210	130.42	5.15	8.98	15.44	K=K @ LIN1
211	131.09		9.27		
212	130.42	5.15	8.39	14.93	K=K @ LIN1
213	130.42	5.15	8.85	15.33	K=K @ LIN1
214	131.09		10.33		
215	130.42	5.15	9.82	16.14	K=K @ LIN1
216	130.42	5.15	9.7	16.04	K=K @ LIN1
217	131.09		10.05		
218	131.09		12.04		
219	130.42	5.15	12.52	18.23	K=K @ LIN1
220	131.09		13.02		
221	130.42	5.15	14.53	19.64	K=K @ LIN1
222	131.09		15.14		
204	131.09		23.49		
223	132.01	5.6	20.31	25.23	
224	131.09		23.83		
225	130.42	5.15	23.78	25.12	K=K @ LIN1
226	131.09		25.29		
227	130.42	5.17	20.25	23.28	K=K @ LIN2
228	132.67		21.05		
229	130.42	5.15	21.56	23.92	K=K @ LIN1
230	132.67		21.98		
231	131.67		25.1		
232	131.67	5.6	25.28	28.16	
233	131.67		32.68		
234	129.42		37.44		
36	129.42		43.58		
37	116.0		50.35		
38	106.5		54.99		
39	106.5		56.66		
TOR	105.83		58.94		

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
BASE	102.83		65.32		
TEST	102.83		65.43	100.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 6
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
HEAD to LIN1	0 0	5.60	14.82 14.82	1 1.049	T 0.0	5.0 0.0 17.000	120 0.0747	7.000 0.0 1.270		Vel = 5.50	
LIN1			0.0 14.82					8.270		K Factor = 5.15	
HEAD2 to LIN2	0 0	5.60	21.00 21.0	1 1.049	T 0.0	5.0 0.0 17.000	120 0.1425	14.062 0.0 2.422		Vel = 7.80	
LIN2			0.0 21.00					16.484		K Factor = 5.17	
200 to 201	131.090 130.420	5.60	23.59 23.59	1 1.049	3E 0.0	6.0 0.0 9.625	120 0.1767	17.752 0.290 1.701		Vel = 8.76	
201 to 203	130.420 131.090	5.15	22.90 46.49	1.25 1.38	E 0.0	3.0 0.0 7.840	120 0.1629	19.743 -0.290 1.277		K = K @ LIN1 Vel = 9.97	
203			0.0 46.49					20.730		K Factor = 10.21	
202 to 203	130.420 131.090	5.15	22.83 22.83	1 1.049	E T 0.0	2.0 5.0 8.330	120 0.1661	19.636 -0.290 1.384		K = K @ LIN1 Vel = 8.48	
203 to 204	131.090 131.090		46.49 69.32	1.25 1.38	T 0.0	6.0 0.0 8.080	120 0.3412	20.730 0.0 2.757		Vel = 14.87	
204			0.0 69.32					23.487		K Factor = 14.30	
205 to 207	130.420 131.090	5.15	14.82 14.82	1 1.049	E T 0.0	2.0 5.0 13.830	120 0.0747	8.270 -0.290 1.033		K = K @ LIN1 Vel = 5.50	
207			0.0 14.82					9.013		K Factor = 4.94	
206 to 207	130.420 131.090	5.15	15.61 15.61	1 1.049		0.0 0.0 1.500	120 0.0820	9.180 -0.290 0.123		K = K @ LIN1 Vel = 5.79	
207 to 209	131.090 131.090		14.82 30.43	1.25 1.38		0.0 0.0 1.960	120 0.0745	9.013 0.0 0.146		Vel = 6.53	
209			0.0 30.43					9.159		K Factor = 10.05	
208 to 209	130.420 131.090	5.15	15.40 15.4	1 1.049	T 0.0	5.0 0.0 6.460	120 0.0802	8.931 -0.290 0.518		K = K @ LIN1 Vel = 5.72	
209 to 211	131.090 131.090		30.42 45.82	1.25 1.38		0.0 0.0 0.670	120 0.1582	9.159 0.0 0.106		Vel = 9.83	
211			0.0 45.82					9.265		K Factor = 15.05	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 7
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
210 to 211	130.420 131.090	5.15	15.44	1	T 0.0	5.0 5.000	120	8.977 -0.290		K = K @ LIN1	
211 to 214	131.090 131.090		15.44	1.049	0.0	7.170	0.0806	0.578		Vel = 5.73	
211 to 214	131.090 131.090		45.82	1.25	0.0	3.920	120	9.265			
214	131.090		61.26	1.38	0.0	3.920	0.2714	1.064		Vel = 13.14	
214			0.0								
214			61.26					10.329		K Factor = 19.06	
212 to 213	130.420 130.420	5.15	14.93	1	0.0	6.000	120	8.394		K = K @ LIN1	
213 to 214	130.420 131.090	5.15	14.93	1.049	0.0	6.000	0.0757	0.454		Vel = 5.54	
213 to 214	130.420 131.090	5.15	15.32	1	T 0.0	5.0 5.000	120	8.848 -0.290		K = K @ LIN1	
214 to 218	131.090 131.090		30.25	1.049	0.0	6.330	0.2798	1.771		Vel = 11.23	
214 to 218	131.090 131.090		61.26	1.25	0.0	3.000	120	10.329			
218	131.090		91.51	1.38	0.0	3.000	0.5703	1.711		Vel = 19.63	
218			0.0								
218			91.51					12.040		K Factor = 26.37	
215 to 217	130.420 131.090	5.15	16.14	1	0.0	6.000	120	9.819		K = K @ LIN1	
217	131.090		16.14	1.049	0.0	6.000	0.0875	0.525		Vel = 5.99	
217			0.0								
217			16.14					10.054		K Factor = 5.09	
216 to 217	130.420 131.090	5.15	16.04	1	E T 5.0	0.500 7.000	120	9.695		K = K @ LIN1	
217 to 218	131.090 131.090		16.04	1.049	0.0	7.500	0.0865	0.649		Vel = 5.95	
217 to 218	131.090 131.090		16.15	1	T 0.0	5.0 5.000	120	10.054			
218 to 220	131.090 131.090		32.19	1.049	0.0	6.330	0.3137	1.986		Vel = 11.95	
218 to 220	131.090 131.090		91.51	1.5	0.0	2.080	120	12.040			
220	131.090		123.7	1.61	0.0	2.080	0.4702	0.978		Vel = 19.49	
220			0.0								
220			123.70					13.018		K Factor = 34.28	
219 to 220	130.420 131.090	5.15	18.23	1	T 0.0	5.0 5.000	120	12.522		K = K @ LIN1	
220 to 222	131.090 131.090		18.23	1.049	0.0	7.170	0.1096	0.786		Vel = 6.77	
220 to 222	131.090 131.090		123.70	1.5	0.0	3.500	120	13.018			
222	131.090		141.93	1.61	0.0	3.500	0.6066	2.123		Vel = 22.37	
222			0.0								
222			141.93					15.141		K Factor = 36.48	
221 to 222	130.420 131.090	5.15	19.64	1	T 0.0	5.0 5.000	120	14.529		K = K @ LIN1	
222 to 204	131.090 131.090		19.64	1.049	0.0	7.170	0.1258	0.902		Vel = 7.29	
222 to 204	131.090 131.090		141.93	1.5	T 0.0	8.0 8.000	120	15.141			
204	131.090		161.57	1.61	0.0	10.830	0.7706	8.346		Vel = 25.46	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 8
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
204 to 224	131.090 131.090		69.31 230.88	3 3.26		0.0 0.0	7.170 0.0	120 0.0480	23.487 0.0			
224			0.0 230.88						23.831		K Factor = 47.29	
223 to 224	132.010 131.090	5.60	25.23 25.23	1 1.049	2E T	4.0 5.0	6.630 9.000	120 0.2001	20.306 0.398			Vel = 9.37
224 to 226	131.090 131.090		230.89 256.12	3 3.26	2E	18.815 0.0	6.250 18.815	120 0.0582	23.831 0.0			Vel = 9.84
226			0.0 256.12						25.290		K Factor = 50.93	
225 to 226	130.420 131.090	5.15	25.12 25.12	1 1.049	E T	2.0 5.0	2.080 7.000	120 0.1985	23.778 -0.290		K = K @ LIN1	Vel = 9.33
226 to 231	131.090 131.670		256.12 281.24	3 3.26		0.0 0.0	0.830 0.0	120 0.0687	25.290 -0.251			Vel = 10.81
231			0.0 281.24						25.096		K Factor = 56.14	
227 to 228	130.420 132.670	5.17	23.28 23.28	1 1.049	E T	2.0 5.0	3.290 7.000	120 0.1723	20.251 -0.974		K = K @ LIN2	Vel = 8.64
228 to 230	132.670 132.670		0.0 23.28	1.25 1.38	2E	6.0 0.0	14.580 6.000	120 0.0453	21.050 0.0			Vel = 4.99
230			0.0 23.28						21.982		K Factor = 4.97	
229 to 230	130.420 132.670	5.15	23.92 23.92	1 1.049	E T	2.0 5.0	0.710 7.000	120 0.1812	21.559 -0.974		K = K @ LIN1	Vel = 8.88
230 to 231	132.670 131.670		23.28 47.2	1.25 1.38	E T	3.0 6.0	7.000 9.000	120 0.1676	21.982 0.433			Vel = 10.12
231 to 232	131.670 131.670		281.24 328.44	3 3.26		0.0 0.0	2.000 2.000	120 0.0925	25.096 0.0			Vel = 12.62
232 to 233	131.670 131.670	5.60	28.16 356.6	3 3.26	V	6.72 0.0	62.250 6.720	120 0.1074	25.281 0.0			Vel = 13.71
233 to 234	131.670 129.420		0.0 356.6	3 3.26	3V	20.159 0.0	15.040 20.159	120 0.1074	32.685 0.974			Vel = 13.71
234 to 36	129.420 129.420		0.0 356.6	3 3.26	B S T	13.44 21.503 20.159	2.125 55.102 57.227	120 0.1074	37.438 0.0 6.144			Vel = 13.71

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 9
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
36 to 37	129.420 116		0.0 356.6	4 4.26	2V 0.0	17.907 17.907	120	43.582 5.812			
						0.0	0.0292	0.958	Vel =	8.03	
37 to 38	116 106.500		0.0 356.6	4 4.26	V 0.0	8.954 8.954	120	50.352 4.114			
						0.0	0.0292	0.525	Vel =	8.03	
38 to 39	106.500 106.500		0.0 356.6	4 4.26	V X B	8.954 21.067 15.8	120	54.991 0.0 1.670			
						15.8	0.0292	1.670	Vel =	8.03	
39 to TOR	106.500 105.830		0.0 356.6	4 4.26	3V T	26.861 26.334	120	56.661 0.290			
						26.334	0.0292	1.984	Vel =	8.03	
TOR to BASE	105.830 102.830		0.0 356.6	4 4.26		0.0 0.0	120	58.935 6.299		** Fixed Loss = 5	
						0.0	0.0293	0.088	Vel =	8.03	
BASE to TEST	102.830 102.830		0.0 356.6	8 8.27	L T G	20.56 55.354 6.326	140	65.322 0.0			
						6.326	0.0009	0.106	Vel =	2.13	
TEST			100.00 456.60					65.428	Qa =	100.00	
									K Factor =	56.45	