

. . . Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 24 PREBLE ST.
Drawing : 2 OF 2
Location : 4TH. FLOOR OFFICE
Remote Area : 4
Contract : 1-05637-SP-17
Data File : 4TH. FLOOR CALC..W XF

HYDRAULIC CALCULATIONS
for

Project name: 24 PREBLE ST.
Location: 4TH. FLOOR OFFICE
Drawing no: 2 OF 2
Date: 8/11/2017

Design

Remote area number: 4
Remote area location: 4TH FLOOR OFFICE
Occupancy classification: LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 936 - SqFt
Coverage per sprinkler: 225 - SqFt
Type of sprinklers calculated: RELIABLE F1FR56 200* K=5.6
No. of sprinklers calculated: 10
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 347.273 - GPM @ 69.784 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 7/6/16
Location: CUMBERLAND AVE. PORTLAND, ME.
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: 170 KITTY HAWK AVE / / AUBURN, ME 04210
Phone number: 207-784-1507
Name of designer: EWM
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.) REMOTE AREA REDUCED PER NFPA 13 (2016) SEC. 11.2.3.2.3.1


Water Supply Curve C

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 2
Date 8/11/2017

City Water Supply:
C1 - Static Pressure : 84
C2 - Residual Pressure: 78
C2 - Residual Flow : 1363

Demand:
D1 - Elevation : 23.569
D2 - System Flow : 247.273
D2 - System Pressure : 69.784
Hose (Demand) : 100
D3 - System Demand : 347.273
Safety Margin : 13.738



Fittings Used Summary

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 3
Date 8/11/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	84.0	78	1363.0	83.522	347.27	69.784

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
HEAD	0.0	5.6	16.14	22.5	
10	160.92	5.6	22.54	26.58	
11	157.92		27.48		
12	157.25	5.24	18.41	22.5	K=K @ LIN1
13	157.92		18.9		
14	157.25	5.24	19.46	23.13	K=K @ LIN1
15	157.92		20.44		
16	157.25	5.24	23.52	25.43	K=K @ LIN1
17	157.92		24.98		
18	157.92		27.48		
19	157.25	5.24	25.09	26.27	K=K @ LIN1
20	157.92		27.54		
21	157.25	5.24	25.99	26.73	K=K @ LIN1
22	157.92		27.58		
23	157.25	5.24	18.71	22.69	K=K @ LIN1
24	157.92		19.16		
25	157.25	5.24	19.14	22.94	K=K @ LIN1
26	157.92		20.41		
27	157.25	5.24	22.59	24.92	K=K @ LIN1
28	157.92		24.0		
29	157.92		27.72		
30	160.92	5.6	21.68	26.07	
30A	157.92		27.6		
31	157.92		28.02		
32	157.92		33.06		
33	153.42		36.37		
34	153.42		39.49		
35	141.42		44.87		
36	129.42		50.56		
37	116.0		56.86		
38	106.5		61.24		
39	106.5		62.09		
TOR	105.83		63.39		
BASE	102.83		69.73		
TEST	102.83		69.78	100.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 5
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
HEAD to LIN1	0 0	5.60	22.50 22.5	1 1.049	E	2.0 0.0 0.0	12.000 2.000 14.000	120 0.1619	16.143 0.0 2.266			Vel = 8.35
LIN1			0.0 22.50						18.409		K Factor =	5.24
10 to 11	160.920 157.920	5.60	26.58 26.58	1 1.049	2E T	4.0 5.0 0.0	7.542 9.000 16.542	120 0.2203	22.536 1.299 3.645			Vel = 9.87
11 to 18	157.920 157.920		0.0 26.58	3 3.26		0.0 0.0 0.0	2.167 0.0 2.167	120 0.0009	27.480 0.0 0.002			Vel = 1.02
18			0.0 26.58						27.482		K Factor =	5.07
12 to 13	157.250 157.920	5.24	22.50 22.5	1 1.049	2E	4.0 0.0 0.0	0.830 4.000 4.830	120 0.1617	18.409 -0.290 0.781		K = K @ LIN1	Vel = 8.35
13 to 15	157.920 157.920		0.0 22.5	1 1.049		0.0 0.0 0.0	9.540 0.0 9.540	120 0.1618	18.900 0.0 1.544			Vel = 8.35
15			0.0 22.50						20.444		K Factor =	4.98
14 to 15	157.250 157.920	5.24	23.13 23.13	1 1.049	E T	2.0 5.0 0.0	0.500 7.000 7.500	120 0.1704	19.456 -0.290 1.278		K = K @ LIN1	Vel = 8.59
15 to 17	157.920 157.920		22.50 45.63	1 1.049		0.0 0.0 0.0	7.580 0.0 7.580	120 0.5985	20.444 0.0 4.537			Vel = 16.94
17			0.0 45.63						24.981		K Factor =	9.13
16 to 17	157.250 157.920	5.24	25.43 25.43	1 1.049	E T	2.0 5.0 0.0	1.625 7.000 8.625	120 0.2030	23.520 -0.290 1.751		K = K @ LIN1	Vel = 9.44
17 to 18	157.920 157.920		45.63 71.06	1.25 1.38	T	6.0 0.0 0.0	1.000 6.000 7.000	120 0.3573	24.981 0.0 2.501			Vel = 15.24
18 to 20	157.920 157.920		26.59 97.65	3 3.26		0.0 0.0 0.0	6.420 0.0 6.420	120 0.0097	27.482 0.0 0.062			Vel = 3.75
20			0.0 97.65						27.544		K Factor =	18.61
19 to 20	157.250 157.920	5.24	26.27 26.27	1 1.049	2E T	4.0 5.0 0.0	3.750 9.000 12.750	120 0.2154	25.088 -0.290 2.746		K = K @ LIN1	Vel = 9.75
20 to 22	157.920 157.920		97.65 123.92	3 3.26		0.0 0.0 0.0	2.250 0.0 2.250	120 0.0156	27.544 0.0 0.035			Vel = 4.76
22			0.0 123.92						27.579		K Factor =	23.60

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 6
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
21 to 22	157.250 157.920	5.24	26.73	1	E T	2.0 5.0	1.460 7.000	120	25.986 -0.290		K = K @ LIN1	
			26.73	1.049		0.0	8.460	0.2226	1.883		Vel = 9.92	
22 to 29	157.920 157.920		123.92	3		0.0 0.0	6.290 0.0	120	27.579 0.0			
			150.65	3.26		0.0	6.290	0.0218	0.137		Vel = 5.79	
			0.0 150.65						27.716		K Factor = 28.62	
23 to 24	157.250 157.920	5.24	22.69	1	2E	4.0 0.0	0.500 4.000	120	18.714 -0.290		K = K @ LIN1	
			22.69	1.049		0.0	4.500	0.1644	0.740		Vel = 8.42	
24 to 26	157.920 157.920		0.0	1		0.0 0.0	7.580 0.0	120	19.164 0.0			
			22.69	1.049		0.0	7.580	0.1642	1.245		Vel = 8.42	
			0.0 22.69						20.409		K Factor = 5.02	
25 to 26	157.250 157.920	5.24	22.94	1	E T	2.0 5.0	2.290 7.000	120	19.141 -0.290		K = K @ LIN1	
			22.94	1.049		0.0	9.290	0.1677	1.558		Vel = 8.52	
26 to 28	157.920 157.920		22.69	1		0.0 0.0	6.000 0.0	120	20.409 0.0			
			45.63	1.049		0.0	6.000	0.5985	3.591		Vel = 16.94	
			0.0 45.63						24.000		K Factor = 9.31	
27 to 28	157.250 157.920	5.24	24.92	1	E T	2.0 5.0	1.710 7.000	120	22.587 -0.290		K = K @ LIN1	
			24.92	1.049		0.0	8.710	0.1955	1.703		Vel = 9.25	
28 to 29	157.920 157.920		45.63	1.25	T	6.0 0.0	4.540 6.000	120	24.000 0.0			
			70.55	1.38		0.0	10.540	0.3526	3.716		Vel = 15.13	
29 to 31	157.920 157.920		150.65	3		0.0 0.0	6.750 0.0	120	27.716 0.0			
			221.2	3.26		0.0	6.750	0.0443	0.299		Vel = 8.50	
			0.0 221.20						28.015		K Factor = 41.79	
30 to 30A	160.920 157.920	5.60	26.07	1	3E	6.0 0.0	15.750 6.000	120	21.677 1.299			
			26.07	1.049		0.0	21.750	0.2125	4.622		Vel = 9.68	
30A to 31	157.920 157.920		0.0	1.25	T	6.0 0.0	1.460 6.000	120	27.598 0.0			
			26.07	1.38		0.0	7.460	0.0559	0.417		Vel = 5.59	
31 to 32	157.920 157.920		221.20	3	2V T	13.44 20.159	58.875 33.599	120	28.015 0.0			
			247.27	3.26		0.0	92.474	0.0545	5.043		Vel = 9.50	
32 to 33	157.920 153.420		0.0	3	2V	13.44 0.0	11.540 13.440	120	33.058 1.949			
			247.27	3.26		0.0	24.980	0.0545	1.362		Vel = 9.50	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
24 PREBLE ST.

Page 7
Date 8/11/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
33 to 34	153.420 153.420		0.0 247.27	3 3.26	B S T	13.44 21.503 20.159	2.125 55.102 57.227	120 36.369 0.0			
								0.0545	3.121	Vel = 9.50	
34 to 35	153.420 141.420		0.0 247.27	4 4.26		0.0 0.0 0.0	12.000 0.0 12.000	120 39.490 5.197			
								0.0148	0.178	Vel = 5.57	
35 to 36	141.420 129.420		0.0 247.27	4 4.26	2V	17.907 0.0 17.907	15.670 17.907 33.577	120 44.865 5.197			
								0.0148	0.498	Vel = 5.57	
36 to 37	129.420 116		0.0 247.27	4 4.26	2V	17.907 0.0 17.907	14.920 17.907 32.827	120 50.560 5.812			
								0.0148	0.487	Vel = 5.57	
37 to 38	116 106.500		0.0 247.27	4 4.26	V	8.954 0.0 8.954	9.040 8.954 17.994	120 56.859 4.114			
								0.0148	0.267	Vel = 5.57	
38 to 39	106.500 106.500		0.0 247.27	4 4.26	V X B	8.954 21.067 15.8	11.420 45.821 57.241	120 61.240 0.0			
								0.0148	0.848	Vel = 5.57	
39 to TOR	106.500 105.830		0.0 247.27	4 4.26	3V T	26.861 26.334 0.0	14.835 53.195 68.030	120 62.088 0.290			
								0.0148	1.008	Vel = 5.57	
TOR to BASE	105.830 102.830		0.0 247.27	4 4.26		0.0 0.0 0.0	3.000 0.0 3.000	120 63.386 6.299		** Fixed Loss = 5	
								0.0150	0.045	Vel = 5.57	
BASE to TEST	102.830 102.830		0.0 247.27	8 8.27	L T G	20.56 55.354 6.326	40.000 82.240 122.240	140 69.730 0.0			
								0.0004	0.054	Vel = 1.48	
TEST			100.00 347.27						69.784	Qa = 100.00 K Factor = 41.57	