DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

Located at

24 PREBLE STREET PROPERTIES LLC

24 PREBLE ST

CBL: 037 F007001

PERMIT ID: 2018-00111 **ISSUE DATE:** 03/07/2018

has permission to Installation of Ansul system.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission pro	cured
before this building or part thereof is lathed or otherw	vise
closed-in. 48 hour notice is required.	

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Michael Russell, MS, Director

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:	
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87	4-8716	2018-00111	01/26/2018	037 F007001	
Proposed Use: Proposed Project Description:					
Same	Installation of Ansul system.				
Dept: Fire Status: Approved w/Conditions Re	eviewer:	Chris Pirone	Approval Da	te: 03/07/2018	
Note:				Ok to Issue: 🔽	
Conditions:					
 Hood suppression system shall comply with NFPA 17A, 96, and U fire alarm system if available. A letter of compliance will be required tested for operation, fuel gas shut off, and fire alarm connection if should be located at the suppression system pull station. Installation shall comply with City Code Chapter 10. A compliance letter stating that the installation meets NFPA codes inspection. The installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City City of Portland Fire Department Rules and Regulations; System acceptance and commissioning must be coordinated with a Fire Department. Call 874-8400 to schedule 	ired at the applicables from the Code;	time of final insp e. The Class K fin installer shall sub	ection stating: the dat re extinguisher and pr mitted electronically	te the system was roper signage prior to the	