



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
PO. BOX 156
MINOT, ME 04258-0258
207-998-2551

Job Name : Teen Sheter Stand Pipe Calc
Building : TEEN SHELTER
Location : 38 PREBLE ST
System : HOSE VALVES
Contract : 042712-1
Data File : HOSE VALVE CALC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - TEEN SHELTER Date - 8-9-12
 Location - 38 PREBLE ST
 Building - TEEN SHELTER System No. - HOSE VALVES
 Contractor - HIGH TECH FIRE PROTECTION Contract No. - 042712-1
 Calculated By - TIM FORITN Drawing No. - FP-01/FP-02
 Occupancy - LIGHT HAZARD

S (X)NFPA 14 Number of Standpipes ()1 (X)2 ()3 ()4 ()
 Y ()Other
 S ()Specific Ruling Made by Date

E	Flow at Top Most Outlet	- 250	Gpm	System Type
M	Pres. at Top Most Outlet	- 21.7	Psi	(X) Wet () Dry
	Flow For Ea. Additional Standpipe	- 250	Gpm	
D	Total Additional Flow	- 450	Gpm	
E	Elevation at Highest Outlet	- 37.5	Feet	
S	Hose Valve Connection	()1 1/2" (X)2 1/2"		
I	Class Service	(X)I ()II ()III		
G	Note:CITY OF PORTLAND PUMPER TRUCK INFO: 1250 GPM AT 150 PSI			
N				

Calculation	Gpm Required 750	Psi Required 21.7	At Test
Summary	C-Factor Used:	Overhead 120	Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test -		Cap.
T	Time of Test -	Rated Cap.	Elev.
E	Static (Psi) - 200	@ Psi	
R	Residual (Psi) - 150	Elev.	Well
	Flow (Gpm) - 1250		Proof Flow Gpm
S	Elevation - 3.5		

U
 P Location: PUMPER TRUCK HOOKED UP TO FIRE DEPARTMENT CONNECTION

P
 L Source of Information: CITY OF PORTLAND

Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 2
Date 7/24/12

City Water Supply:
 C1 - Static Pressure : 200
 C2 - Residual Pressure: 150
 C2 - Residual Flow : 1250

Demand:
 D1 - Elevation : 16.241
 D2 - System Flow :
 D2 - System Pressure : 21.744
 Hose (Adj City) :
 Hose (Demand) : 750
 D3 - System Demand : 750
 Safety Margin : 158.823



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 3
Date 7/24/12

Fitting Legend																				
Abbrev. Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 4
Date 7/24/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
HV1	37.5		0.0	na	250.0			
HV2	25.5		5.38	na	250.0			
S	37.5		0.11	na				
S1	25.5		5.49	na				
S2	12.5		11.77	na				
S3	9.0		13.94	na				
S4	9.0		14.02	na				
S5	9.0		16.06	na				
HV3	37.5		4.55	na	250.0			
R3	37.5		4.63	na				
R2	25.5		9.88	na				
R1	12.5		15.69	na				
S6	3.5		19.71	na				
TEST	0.0		21.74	na				

The maximum velocity is 16.88 and it occurs in the pipe between nodes S6 and TEST

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 5
Date 7/24/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HV1	250.00	2.469	0.0	0.500	0.0			Qa = 250	
to		120.0	0.0	0.0	0.0				
S	250.0	0.2160	0.0	0.500	0.108			Vel = 16.75	
	0.0								
	250.00				0.108			K Factor = 760.73	
HV2	250.00	2.469	0.0	0.500	5.379			Qa = 250	
to		120.0	0.0	0.0	0.0				
S1	250.0	0.2140	0.0	0.500	0.107			Vel = 16.75	
	0.0								
	250.00				5.486			K Factor = 106.74	
S	250.00	4.26	0.0	12.000	0.108				
to		120.0	0.0	0.0	5.197				
S1	250.0	0.0151	0.0	12.000	0.181			Vel = 5.63	
S1	250.00	4.26	0.0	12.000	5.486				
to		120.0	0.0	0.0	5.630				
S2	500.0	0.0546	0.0	12.000	0.655			Vel = 11.25	
S2	0.0	4.26	0.0	12.000	11.771				
to		120.0	0.0	0.0	1.516				
S3	500.0	0.0545	0.0	12.000	0.654			Vel = 11.25	
S3	0.0	4.26	0.0	1.500	13.941				
to		120.0	0.0	0.0	0.0				
S4	500.0	0.0547	0.0	1.500	0.082			Vel = 11.25	
S4	0.0	4.26	0.0	37.300	14.023				
to		120.0	0.0	0.0	0.0				
S5	500.0	0.0545	0.0	37.300	2.033			Vel = 11.25	
S5	0.0	4.26	0.0	23.300	16.056				
to		120.0	0.0	0.0	2.382				
S6	500.0	0.0545	0.0	23.300	1.270			Vel = 11.25	
	0.0								
	500.00				19.708			K Factor = 112.63	
HV3	250.00	2.635	0.0	0.500	4.549			Qa = 250	
to		120.0	0.0	0.0	0.0				
R3	250.0	0.1580	0.0	0.500	0.079			Vel = 14.71	
R3	0.0	4.26	0.0	3.500	4.628				
to		120.0	0.0	0.0	5.197				
R2	250.0	0.0151	0.0	3.500	0.053			Vel = 5.63	
R2	0.0	4.26	0.0	12.000	9.878				
to		120.0	0.0	0.0	5.630				
R1	250.0	0.0152	0.0	12.000	0.182			Vel = 5.63	
R1	0.0	4.26	0.0	8.000	15.690				
to		120.0	0.0	0.0	3.898				
S6	250.0	0.0150	0.0	8.000	0.120			Vel = 5.63	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 6
Date 7/24/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 250.00					19.708		K Factor = 56.31	
S6 to TEST	750.00 750.0	4.26 120.0 0.1156	0.0 0.0 0.0	4.500 0.0 4.500	19.708 1.516 0.520			Vel = 16.88	
	0.0 750.00					21.744		K Factor = 160.84	